

Type Test Certificate — Power Electronics FS3450

ENA Engineering Recommendation G99 Issue 2

Equipment	Power Electronics FS3450 inverter
Standard	ENA G99 Issue 2
Certificate ref	PE-G99v2-2025-1180
Control mode	Grid-following (current-source)

1. Certification statement

This certifies that the inverter has been type-tested in accordance with ENA Engineering Recommendation G99 Issue 2.

2. Control mode

2.1 Control mode: grid-following (current-source) operation. The unit was NOT tested for grid-forming (voltage-source) operation, and no virtual-inertia capability is certified under this report.

3. Verified capabilities

Verified in grid-following mode: low-voltage ride-through (LVRT); reactive capability; and frequency response. Grid-forming behaviour, synthetic inertia, and fault-level contribution as a voltage source are outside the scope of this certificate.

Test results summary

Test	Mode	Result
LVRT	grid-following	Pass
Reactive capability	grid-following	Pass
Frequency response	grid-following	Pass
Grid-forming / inertia	—	Not tested