

Grid Interconnection Application Form

Transmission connection — generation

PROJECT ID: TX-GEN-001

PROJECT NAME: Thornholme Wind Farm

APPLICANT: Thornholme Renewables Ltd

LEVEL: transmission

CONNECTION TYPE: generation

CAPACITY: 400 MW onshore wind

STATUS: Under review

DATE SUBMITTED: 2026-04-18

SECTION 1: Site & location

REQUIREMENT:

Site address plus GPS coordinates (WGS84, 3 d.p.). Source: Gate 2 Criteria Methodology §4.1b.

SUBMITTED:

Thornholme Moor, near Driffield, East Riding of Yorkshire, YO25 3QF. Point of connection at 54.012 N, -0.471 E (WGS84). The site abuts the existing 400 kV Creyke Beck corridor approximately 6 km to the west.

SUPPORTING DOCS:

red_line_boundary_plan.pdf

SECTION 2: Land — control

REQUIREMENT:

Evidence of land rights — freehold, lease, or option agreement of at least 20 years. Source: Gate 2 §4.1c.

SUBMITTED:

The developer holds an executed option-to-lease over the entire red-line area. Land rights are secured for the operational life of the project, satisfying the Gate 2 land-control readiness criterion.

SUPPORTING DOCS:

land_lease_agreement.pdf

SECTION 3: Planning

REQUIREMENT:

Planning consent status — submitted, granted, or DCO (projects above 50 MW onshore use the DCO route). Source: Gate 2 §5.

SUBMITTED:

The project exceeds 50 MW onshore and is consented under a Development Consent Order granted by the Secretary of State on 2025-11-03 (ref. EN010142). The DCO authorises up to 420 MW of installed capacity.

SUPPORTING DOCS:

planning_consent.pdf

SECTION 4: Project capacity

REQUIREMENT:

Megawatt capacity per technology plus total connection capacity requested. Source: CUSC §2.2.4; Gate 2 §4.1b.

SUBMITTED:

Total Transmission Entry Capacity (TEC) requested: 400 MW. Single technology (onshore wind), 80 x 5 MW turbines. No phased ramp; full capacity sought from the connection date.

SUPPORTING DOCS:

none

SECTION 5: Company

REQUIREMENT:

Corporate identity, ownership, and financial standing. Source: CUSC Schedule 2 Exhibit B; CUSC §2 Part III.

SUBMITTED:

Thornholme Renewables Ltd (company no. 11234567) is a wholly owned subsidiary of Northbank Energy Capital. Audited net assets of £182m and committed equity of £140m are available for the project.

SUPPORTING DOCS:

financial_statement.pdf

SECTION 6: Plant — protection

REQUIREMENT:

Protection relay settings and fault-clearance times that align with the network's own protection. Source: CUSC Appendix F4.

SUBMITTED:

Main and backup distance protection with a fault-clearance time of 80 ms at the 400 kV point of connection, co-ordinated with NESO's Creyke Beck zone settings. Full F4 schedule attached.

SUPPORTING DOCS:

protection_settings_f4.pdf

SECTION 7: Network studies

REQUIREMENT:

Steady-state load flow, fault-level analysis, and transient stability assessment. Source: Grid Code Connection Conditions; CNDM Dec 2025.

SUBMITTED:

Load-flow and fault-level studies completed against the 2030 NESO base case show no thermal or voltage violations. Transient stability confirmed for the three-phase fault-ride-through envelope.

SUPPORTING DOCS:

none