

Interface Protection Settings Schedule

Greenholt Solar Park — 33 kV point of connection

Voltage protection: $U <$ stage 1 -13% 2.5 s; $U <$ stage 2 -20% 0.5 s; $U >$ stage 1 +10% 1.0 s; $U >$ stage 2 +13% 0.5 s.

Frequency protection: $f <$ 47.5 Hz 20 s; $f <$ 47.0 Hz 0.5 s; $f >$ 51.5 Hz 90 s; $f >$ 52.0 Hz 0.5 s.

Note: the loss-of-mains (RoCoF) element and its stability setting are to be confirmed at the commissioning stage and are not included in this schedule.