

Single-Line Diagram — Greenholt Solar Park

24 MW PV connection to Greenholt 33 kV primary

PV array of 6 x 4 MW blocks, each with a 4 MVA 0.69/33 kV transformer, combined onto a 33 kV switchboard.

Single point of connection to the DNO 33 kV busbar at Greenholt primary, via a metered circuit breaker with interface protection.

Maximum export 24 MVA; site auxiliary import 0.5 MVA.