

Type Test Certificate — Sungrow SG3600UD-MV

Engineering Recommendation G99 compliance

This certifies that the Sungrow SG3600UD-MV power unit has been tested in accordance with the type-test requirements of ENA Engineering Recommendation G99 Issue 1.

Verified capabilities: reactive power capability, voltage ride-through, frequency response, and protection function operation.

Certificate issued by an accredited test laboratory; reference SGR-G99-2024-0417.