

# Single-Line Diagram — Riverside BESS

8 MW / 16 MWh connection to 11 kV

---

Four 2 MW inverter-transformer skids combined onto an 11 kV switchboard, connected to the DNO 11 kV network via a metered ring main unit.

A grid-charging path is provided: the BESS can import from the 11 kV network as well as export.

Site auxiliary supply taken from the LV board of skid 1.