

Type Test Certificate — Power Electronics FS3450

Engineering Recommendation G99 Issue 2

This certifies that the inverter has been type-tested in accordance with ENA Engineering Recommendation G99 Issue 2.

Control mode: grid-following (current-source) operation. The unit was not tested for grid-forming (voltage-source) operation, and no virtual inertia capability is certified under this report.

Verified: LVRT, reactive capability, and frequency response in grid-following mode. Reference PE-G99v2-2025-1180.