

# CUSC Appendix F4 — Protection Settings Schedule

Thornholme 400 kV connection

---

Main protection: dual-redundant distance protection (Zone 1 reach 80% of line, instantaneous; Zone 2 120%, 350 ms).

Backup protection: directional earth-fault and overcurrent.

Total fault-clearance time at the point of connection: 80 ms for a three-phase fault, within the NESO Creyke Beck zone requirement of 100 ms. Breaker-fail protection set at 150 ms.