

Single-Line Diagram — Pennine BESS

200 MW / 800 MWh connection to 275 kV Stalybridge

The site connects to the 275 kV busbar at Stalybridge via a 200 MVA 275/33 kV grid transformer and a 33 kV switchboard.

Power conversion: 40 x 5 MW grid-forming inverters arranged in 8 blocks, each block with its own 33/0.69 kV transformer.

Metering point at the 275 kV connection. Export limited at the site controller to the registered Transmission Entry Capacity.