

FORM REF	1725IED-FAT-TR-PWR		
FORM DESCRIPTION	RTU FAT RECORD – RTU POWER UP	FORM VERSION	02
PROJECT DETAILS	RTU SERIAL NO:	PRODUCT DETAILS	DF1725IED RTU
	CONTRACT NO:	TEST RECORD SHEET	28 of 39
FAT – TEST RECORD REF:	RTU POWER UP	RECORD SHEET NO.	of

1.0 RTU Power Up

No.	Test Parameter	Actual Reading	OK	NO
1	Panel Input Voltage (DC) = 110/48/30/24 Vdc			
2	Panel Input Voltage (AC) = 240 Vac			

No.	Inspection	OK	NO
1	The DC Lamp indication is 'ON' with GREEN LED.		
2	The Alarm Lamp indication is 'ON' with RED LED.		
3	The Dummy Breaker LED is 'OPEN = GREEN' or 'CLOSE = RED'.		
4	The panel light is 'ON' when door panel is opened. Panel light is 'OFF' when Door Switch is pressed.		
5	The 3 Pin 13A Socket is functional and can be used.		



Tested By:
(Signature/Official Stamp)

Witnessed By:
(Signature/Official Stamp)

Tester's
Name:
Date:

TNB QAI's
Name: Muhammad Azamuddin Bin Hasan
Date:

