

| | | | |
|------------------------|---------------------------------|-------------------|---------------|
| FORM REF | 1725IED-FAT-TR-FTVA | | |
| FORM DESCRIPTION | RTU FAT RECORD – VIRTUAL ALARM | FORM VERSION | 02 |
| PROJECT DETAILS | RTU SERIAL NO: | PRODUCT DETAILS | DF1725IED RTU |
| | CONTRACT NO: | TEST RECORD SHEET | 37 of 39 |
| FAT – TEST RECORD REF: | FUNCTIONAL TEST – VIRTUAL ALARM | RECORD SHEET NO. | 1 of 1 |


1.0 Virtual Alarm Test

| Virtual Alarm | IOA/Index | | |
|----------------------|--------------------------|--------------------------|--------------------------|
| | IEC101 | IEC104 | DNP3 |
| SOE Buffer Full | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Time Sync Alarm | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| RTU Health/Comm Fail | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| DI Module Fail | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| DO Module Fail | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| AI Module Fail | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| AO Module Fail | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |



Tested By:
(Signature/Official Stamp)

Witnessed By:
(Signature/Official Stamp)



Tester's
Name:
Date:

TNB QAI's
Name: Muhammad Azamuddin Bin Hasan
Date: