

FORM REF	1725IED-FAT-TR-PIPN		
FORM DESCRIPTION	RTU FAT RECORD – INSPECTION	FORM VERSION	02
PROJECT DETAILS	RTU SERIAL NO:	PRODUCT DETAILS	DF1725IED RTU
	CONTRACT NO:	TEST RECORD SHEET	16 of 39
FAT – TEST RECORD REF:	INSPECTION – RTU PANEL	RECORD SHEET NO.	1 of 1

1.0 Panel Information

No.	Description	Record
1	RTU Serial No.	

2.0 Physical and Quality Inspection

No.	Inspection	Measurement (mm)	Manufacturer Tolerance	OK	NO
1	Panel Height		±5%		
2	Panel Width		±5%		
3	Panel Depth		±5%		

No	Inspection	OK	NO
1	The panel is free from defect e.g. scratches, deformities, corrosion, broken.		
2	The wirings are neat, tidy, proper, and accessible.		
3	The wire marker and ferrules are available, proper, and correct.		
4	The wire marker has source and destination stated.		
5	The terminal block arrangement is proper and tidy.		
6	All LED indicators are correct as per approved drawing.		



Tested By:
(Signature/Official Stamp)

Witnessed By:
(Signature/Official Stamp)

Tester's
Name:
Date:

TNB QAI's
Name: Muhammad Azamuddin Bin Hasan
Date: