1.0 Physical and Quality Inspection

AI No.	Part Number	Subrack No.	Slot No.	Serial Number

No.	Quality Inspection	OK	NO
1	The module is free from defect e.g. scratches, deformities, corrosion, broken.	☐	☐
2	The jumper is set as per approved drawing.	☐	☐

2.0 Functional Test – Analog Input Module

Notes: Please write the report value reading in the Result box.

Point No.	Test							IOA/Index		
	Current	0mA	4mA	8mA	12mA	16mA	20mA			
	Raw	-2490 – -2510	-10 – 10	2490 – 2510	4990 – 5010	7940 – 7510	9990 – 10010			
	Report	-8158 – -8225	-33 – 33	8158 – 8225	16350 – 16416	24542 – 24608	32734 – 32799	IEC101	IEC104	DNP3
1	Result									N/A
2										N/A
3										N/A
4										N/A
5										N/A
6										N/A
7										N/A
8										N/A

Ir. Ts. RAMLAH
19 DEC 24
ES
DISTRIBUTION NETWORK DIVISION, TNB

Tested By:
(Signature/Official Stamp)

Tester's
Name:
Date:

Witnessed By:
(Signature/Official Stamp)

AZAMUDDIN
QUALITY ASSURANCE EXECUTIVE
GRID VISION T&D S/B

TNB QAI's
Name: Muhammad Azamuddin Bin Hasan
Date: