1.0 Approved Drawings

Drawing Title	Drawing No.	Revision	Approved Date	OK
Telecontrol Overview Drawing	GV TNBD 0614 B02 TOD			☐
RTU Configuration Drawing	GV TNBD 0614 B01 RCF			☐
RTU Cubicle Internal Wiring Drawing	GV TNBD 0614 V01 RIW			☐
RTU Cubicle Drawing	GV TNBD 0614 U01 CDW			☐
RTU Parameter List	GV TNBD 0614 T01 PM			☐
RTU Cable Drawing	GV TNBD 0614 T11 RCS			☐

2.0 Bill of Quantity

No.	Module Name	Part Number	Quantity	Firmware Version
1	RTU Subrack	1725IED_SUBRACK 19”		N/A
2	RTU Subrack	1725IED_SUBRACK 2/3 19”		N/A
3	RTU Subrack	1725IED_SUBRACK 1/2 19”		N/A
4	RTU Processor Board	1725IED_MCU-1-A		4.11.024 24 Aug 2024
5	RTU Processor Board	1725IED_MCU-4-A		4.02.008 24 Nov 2023
6	RTU Digital Input Module	1725IED_DI-32-24V		N/A
7	RTU Digital Input Module	1725IED_DI-16-24V-A		N/A
8	RTU Digital Input Module	1725IED_DI-16-110V		N/A
9	RTU Digital Output Module	1725IED_CO-8-A		N/A
10	RTU Digital Output Module	1725IED_CO-16-A		N/A
11	RTU Analog Input Module	1725IED_DCAI-8-A		N/A
12	110/220V Power Supply Board	1725IED_POWER-110/220V		N/A
13	24V Power Supply Board	1725IED_POWER-24V-A		N/A
14	Communication Module	1725IED_COM-6-A		N/A

Ir. Ts. RAMLAH
19 DEC 24
ES
DISTRIBUTION NETWORK DIVISION TNB

3.0 SGP Certificate

Item	Serial Number
DF1725IED RTU SGP Certificate	D2023–0510:0014

4.0 Panel IP Certificate

No.	RTU Panel Type	IP Rating	Certificate Number	Applicable
1	Floor Standing – Indoor	IP51	2017EEA0204	☐
2	Floor Standing – Outdoor	IP54	2021EA1541	☐
3	Wall Mounted – Indoor	IP51	2015EEA0091	☐
4	Wall Mounted – Outdoor	IP54	2021EA1540	☐

5.0 Test Equipment Record

No.	Item	Brand	Model	Serial Number
1				
2				
3				

6.0 Measuring Equipment Record

No.	Item	Brand	Model	Serial Number	Calibration Date	Calibration Due Date
1						
2						
3						
4						

Ir. Ts. RAMLAH
19 DEC 24
ES
DISTRIBUTION NETWORK DIVISION, TNB

7.0 Software Record

No.	Item	Brand	Software Name	Version	OK
1	Diagnostic/Configuration Tool	Dong Fang	DFE Engineering Tool Software	3.02.009	☐
2	IEC101/IEC104/DNP3.0 Master Simulator	ASE	ASE2000 Version 1	1.56	☐

8.0 Pre-FAT Record

Pre-FAT Date	N/A
Pre-FAT Result	N/A
Remarks/Notes	N/A

9.0 Tester's Competency

No.	Tester's Name	Years of Experience
1		
2		

Ir. Ts. RAMLAH
19 DEC 24
ES
DISTRIBUTION NETWORK DIVISION, TNB

Tested By:
(Signature/Official Stamp)

Tester's
Name:
Date:

Witnessed By:
(Signature/Official Stamp)

AZAMUDDIN
QUALITY ASSURANCE EXECUTIVE
GRID VISION T&D SIB

TNB QAI's
Name: Muhammad Azamuddin Bin Hasan
Date: