

|                        |                             |                   |               |
|------------------------|-----------------------------|-------------------|---------------|
| FORM REF               | 1725IED-FAT-TR-PIAI         |                   |               |
| FORM DESCRIPTION       | RTU FAT RECORD – INSPECTION | FORM VERSION      | 02            |
| PROJECT DETAILS        | RTU SERIAL NO:              | PRODUCT DETAILS   | DF1725IED RTU |
|                        | CONTRACT NO:                | TEST RECORD SHEET | 26 of 39      |
| FAT – TEST RECORD REF: | INSPECTION – AI MODULE      | RECORD SHEET NO.  | of            |

## 1.0 Physical and Quality Inspection

| AI No. | Part Number | Subrack No. | Slot No. | Serial Number |
|--------|-------------|-------------|----------|---------------|
|        | DCAI-8-A    |             |          |               |

| No. | Quality Inspection                                                             | OK                       | NO                       |
|-----|--------------------------------------------------------------------------------|--------------------------|--------------------------|
| 1   | The module is free from defect e.g. scratches, deformities, corrosion, broken. | <input type="checkbox"/> | <input type="checkbox"/> |
| 2   | The jumper is set as per approved drawing.                                     | <input type="checkbox"/> | <input type="checkbox"/> |

## 2.0 Functional Test – Analog Input Module

Notes: Please tick the checkboxes if the readings are within the report value range.

| Point No. | Test    |               |          |             |               |               |               | IOA/Index |        |      |
|-----------|---------|---------------|----------|-------------|---------------|---------------|---------------|-----------|--------|------|
|           | Current | 0mA           | 4mA      | 8mA         | 12mA          | 16mA          | 20mA          |           |        |      |
|           | Raw     | -2490 – -2510 | -10 – 10 | 2490 – 2510 | 4990 – 5010   | 7940 – 7510   | 9990 – 10010  |           |        |      |
|           | Report  | -8158 – -8225 | -33 – 33 | 8158 – 8225 | 16350 – 16416 | 24542 – 24608 | 32734 – 32799 | IEC101    | IEC104 | DNP3 |
| 1         | Result  |               |          |             |               |               |               |           |        | N/A  |
| 2         |         |               |          |             |               |               |               |           |        | N/A  |
| 3         |         |               |          |             |               |               |               |           |        | N/A  |
| 4         |         |               |          |             |               |               |               |           |        | N/A  |
| 5         |         |               |          |             |               |               |               |           |        | N/A  |
| 6         |         |               |          |             |               |               |               |           |        | N/A  |
| 7         |         |               |          |             |               |               |               |           |        | N/A  |
| 8         |         |               |          |             |               |               |               |           |        | N/A  |



Tested By:  
(Signature/Official Stamp)

Witnessed By:  
(Signature/Official Stamp)

Tester's  
Name:  
Date:

TNB QAI's  
Name:  
Date: