1.0 RTU Power Up

No.	Test Parameter	Actual Reading	OK	NO
1	Panel Input Voltage (DC) = 110/48/30/24 Vdc		☐	☐
2	Panel Input Voltage (AC) = 240 Vac		☐	☐

No.	Inspection	OK	NO
1	The DC Lamp indication is 'ON' with GREEN LED.	☐	☐
2	The Alarm Lamp indication is 'ON' with RED LED.	☐	☐
3	The Dummy Breaker LED is 'OPEN = GREEN' or 'CLOSE = RED'.	☐	☐
4	The panel light is 'ON' when door panel is opened. Panel light is 'OFF' when Door Switch is pressed.	☐	☐
5	The 3 Pin 13A Socket is functional and can be used.	☐	☐

Ir. Ts. RAMLAH
19 DEC 24
ES
DISTRIBUTION NETWORK DIVISION TNB

Tested By:
(Signature/Official Stamp)

Tester's
Name:
Date:

Witnessed By:
(Signature/Official Stamp)

AZAMUDDIN
QUALITY ASSURANCE EXECUTIVE
GRID VISION T&D S/B

TNB QAI's
Name: Muhammad Azamuddin Bin Hasan
Date: