

FORM REF	1725IED-FAT-TR-PIDO		
FORM DESCRIPTION	RTU FAT RECORD – INSPECTION	FORM VERSION	02
PROJECT DETAILS	RTU SERIAL NO:	PRODUCT DETAILS	DF1725IED RTU
	CONTRACT NO:	TEST RECORD SHEET	25 of 39
FAT – TEST RECORD REF:	INSPECTION – DO MODULE	RECORD SHEET NO.	of

3.0 Dummy Breaker and CES Functional Test

No.	Inspection	OK	NO
1	During CES ON: Dummy Breaker LED turns GREEN when Dummy CB Open command is sent.		
2	During CES ON: Dummy Breaker LED turns RED when Dummy CB Close command is sent.		
3	During CES OFF: Dummy Breaker LED remain unchanged when Dummy CB Open command is sent.		
4	During CES OFF: Dummy Breaker LED remain unchanged when Dummy CB Close command is sent.		

4.0 Buzzer Test

No.	Inspection	OK	NO
1	During CES ON: Close the Panel Door. No Buzzer should be triggered.		
2	During CES OFF: Close the Panel Door. Buzzer should be triggered.		



Tested By:
(Signature/Official Stamp)

Witnessed By:
(Signature/Official Stamp)



Tester's
Name:
Date:

TNB QAI's
Name: Muhammad Azamuddin Bin Hasan
Date: