

|                        |                               |                   |               |
|------------------------|-------------------------------|-------------------|---------------|
| FORM REF               | 1725IED-FAT-TR-PWR            |                   |               |
| FORM DESCRIPTION       | RTU FAT RECORD – RTU POWER UP | FORM VERSION      | 02            |
| PROJECT DETAILS        | RTU SERIAL NO:                | PRODUCT DETAILS   | DF1725IED RTU |
|                        | CONTRACT NO:                  | TEST RECORD SHEET | 28 of 39      |
| FAT – TEST RECORD REF: | RTU POWER UP                  | RECORD SHEET NO.  | of            |

## 1.0 RTU Power Up

| No. | Test Parameter                              | Actual Reading | OK | NO |
|-----|---------------------------------------------|----------------|----|----|
| 1   | Panel Input Voltage (DC) = 110/48/30/24 Vdc |                |    |    |
| 2   | Panel Input Voltage (AC) = 240 Vac          |                |    |    |

| No. | Inspection                                                                                           | OK | NO |
|-----|------------------------------------------------------------------------------------------------------|----|----|
| 1   | The DC Lamp indication is 'ON' with GREEN LED.                                                       |    |    |
| 2   | The Alarm Lamp indication is 'ON' with RED LED.                                                      |    |    |
| 3   | The Dummy Breaker LED is 'OPEN = GREEN' or 'CLOSE = RED'.                                            |    |    |
| 4   | The panel light is 'ON' when door panel is opened. Panel light is 'OFF' when Door Switch is pressed. |    |    |
| 5   | The 3 Pin 13A Socket is functional and can be used.                                                  |    |    |



Tested By:  
(Signature/Official Stamp)

Witnessed By:  
(Signature/Official Stamp)

\_\_\_\_\_  
Tester's  
Name:  
Date:

\_\_\_\_\_  
TNB QAI's  
Name:  
Date: