



河北易达核联机械制造股份有限公司
Hebei Yida United Machinery Co.,Ltd.
质量合格证明书
QUALITY CERTIFICATE



质量记录编号: 202607025-01

签发日期: 2026.07.25

序号 Number		货物描述 Product Name		型号 Specification	涂层 Finish	螺纹规格 Thread Specification	尺寸 Size	批次号 Batch Number				数量(支) Quantity (pcs)	外观 Appearance	包装 Packing	
1		Rebar Coupler		D32	Plain	M36*4.0	50*72	Hebei Yida D32 DCL 202607/2859/T2				82944	OK	OK	
2		Rebar Coupler		D32	Plain	M36*4.0	50*72	Hebei Yida D32 DCL 202607/2862/T2				57600	OK	OK	
3		Rebar Coupler		D32	Plain	M36*4.0	50*72	Hebei Yida D32 DCL 202607/2955/T2				59456	OK	OK	
原材料检测 Raw Material Inspection															
序号 Number	牌号 Material	规格 Specif ication	炉号 Heat Number	执行标准 Exec. Standard	抗拉 Tensile Rm ≥590Mpa	屈服强度 Yield Strength ReL ≥335Mpa	延伸 Elongation A% ≥14%	化学成分 Chemical Composition (%)							
								C	Si	Mn	P	S	Cr	Ni	Cu
1	#45	55	32512859-01	GB/T699-2015	650	402	22.5	0.44	0.19	0.57	0.020	0.012	0.020	0.005	0.008
2		55	32512862-01		653	399	22	0.46	0.18	0.58	0.012	0.008	0.020	0.008	0.011
3		55	22512955-01		644	392	22.5	0.46	0.19	0.58	0.015	0.017	0.020	0.006	0.008
成品检测 LOAD TEST															
Exec.Standard		ISO15835-2													
项目 Item		静态滑移 Static Slip		极限抗拉强度 Ultimate Tensile Strength			最大力下延伸率 Elongation at Max.Force , Agt		断裂位置 Position Of Fracture				低周往复荷载试验 Low-cycle Reversed Loading Test		
		≤0.10mm		≥600Mpa			≥5%								
规格 Specification	32	0.02		707			10%		机械连接长度外钢筋断裂 Outside the mechanical splice length				符合要求 Meets the requirements		
	32	0.04		710			11%		机械连接长度外钢筋断裂 Outside the mechanical splice length				符合要求 Meets the requirements		
	32	0.02		711			11%		机械连接长度外钢筋断裂 Outside the mechanical splice length				符合要求 Meets the requirements		
检验员: GUO KEJIAN															