

Confirmed Release Report

Owner Information

Kirco ET CH Distribution II LLC
101 W Big Beaver Rd
Troy, MI 48084

Owner Phone#: (248) 680-7180
Contact Person:

Location of Tanks

Facility ID: 00042491
Cardinal Health
5940 Avery
5940 Avery St
Detroit, MI 48208

Facility County: Wayne

Release Discovery Details :

Leak ID: C-0049-14
Date / Time Released Reported : 05/09/2014 09:52 AM

Reporting Party Information :

Name: Thomas Szocinski, Consultant
Company: AKT Peerless
Phone#: (248) 615-1333

Release Status

Release Type	Discovery Date / Time	Upgrade / Cancel Date	Correspondence	Correspondence Date	Comments
Confirmed Release	05/08/2014 12:00 PM		Confirmed Confirmation To Owner/Operator	05/15/2014	

Tank Information and Product Released

Tank ID	Capacity (Gallons)	Substance Released	Cause of Release							How was Leak Detected						
			Tank	Piping	Spill Protection	Overfill Protection	Dispenser	Unknown	Other	Tank Removal	Inventory Records	Repairs	Stained Soil	Petroleum Odors	Analytical Data	Free Product and/or Oil Sheen in Groundwater
1	1,000	Used Oil	x							x						

Comments:

Upon removal of the UST, holes were identified in the UST and impacted soils were identified surrounding the UST.

☒ **NEW Release**
☐ **PREVIOUS Release**
☐ **File Name correct?** *James*
 (if not, Please indicate change at top)