



Therapy Spaces

16 St James Road Surbiton KT6 4QH

Emergency Action Plan (EAP)

16 St James' Road London KT6 4QH

Foreseeable Events:

1. Electrical Fire
2. Non-electrical Fire

Action on Discovering a Fire:

1. Raise alarm – there is a push alarm in the reception area.
2. Escort all clients from the premises to the assembly point.
3. If possible contain fire using fire fighting equipment provided there is no risk to person.
4. Telephone the emergency services (999) if required.
5. Contact the branch supervisor. (07710 132 221)
6. Liaise with the Fire Service when they arrive.

Assembly point:

The car park of the Surbiton Club

Escape Routes:

The escape Route is through the front entrance of the shop

Fire Fighting Equipment:

A CO2 and a water fire extinguisher are located by the WC.

Isolating Electrical Equipment:

Where necessary, electrical equipment can be isolated by switching off the mains electricity at the consumer unit in the cupboard in therapy room 4.

Last Reviewed: 08/05/2021 PAS

Note – This document should only be reprinted where reviews result in changes – to check on the last review date refer to the electronic copy.