Safe Work Method Statement (SWMS)

Ceiling insulation (VEU Activity 48) — Job HV-TEST-0358

BUSINESS (DIRECT EMPLOYER) TEST Insulation Co Pty Ltd	**PRINCIPAL CONTRACTOR** Home Insulation Victoria (DC Construction Solutions Pty Ltd)
WORK SUPERVISOR TEST Lead Installer	**INSTALL DATE** 03/11/2026
SITE LOCATION / ADDRESS 1 Test Street, Testville, 3999	**WORK ACTIVITY** Ceiling insulation removal (if required) and installation of bulk ceiling insulation – VEU Activity 48
HIGH-RISK CONSTRUCTION WORK • Risk of a person falling more than 2 metres (ladder, manhole, roof, ceiling joists) • Work on or near energised electrical installations or services (ceiling cables, switchboard, solar/battery) • Work that may disturb asbestos (home built before 1990, or asbestos suspected)	
PERSON RESPONSIBLE FOR ENSURING COMPLIANCE WITH SWMS TEST Lead Installer	**MEASURES TO ENSURE COMPLIANCE** Direct supervision by the lead installer; every control checked before first entry and at the start of each day
HOW CONTROL MEASURES WILL BE REVIEWED The lead installer re-checks every control at the start of each day before work, and the plan is reviewed if anything on site changes	

Tasks, hazards and control measures

Tasks	Hazard	Control measures	How implemented	Responsible
Ceiling insulation removal (if required) and installation in the ceiling space	**Live electrical hazards**	Live electrical: power isolated, locked out and tagged before entry (solar, battery and generator too, following their instructions); PIESA read and its conditions followed; electrician on site when the PIESA requires; test for dead before touching cables.	Lead installer directly supervises the crew, checks the control before anyone enters the ceiling and again at the start of each day, and stops work if it cannot be followed	TEST Lead Installer (lead installer)
Ceiling insulation removal (if required) and installation in the ceiling space	**Hazardous substances (friable asbestos, harmful chemicals)**	Hazardous substances: if asbestos is suspected, do not disturb it — stop work; it is a licensed asbestos removalist's job before work continues; no chemicals or solvents used in the ceiling.	Lead installer directly supervises the crew, checks the control before anyone enters the ceiling and again at the start of each day, and stops work if it cannot be followed	TEST Lead Installer (lead installer)
Ceiling insulation removal (if required) and installation in the ceiling space	**Biological hazards (mould, animal waste)**	Biological (mould, animal waste): do not disturb droppings or mould dry; P2 mask and gloves; wash hands before eating.	Lead installer directly supervises the crew, checks the control before anyone enters the ceiling and again at the start of each day, and stops work if it cannot be followed	TEST Lead Installer (lead installer)
Ceiling insulation removal (if required) and installation in the ceiling space	**High temperatures and heat exhaustion**	Heat: work early, water and a break every 30 minutes, stop in extreme heat.	Lead installer directly supervises the crew, checks the control before anyone enters the ceiling and again at the start of each day, and stops work if it cannot be followed	TEST Lead Installer (lead installer)

Tasks	Hazard	Control measures	How implemented	Responsible
Ceiling insulation removal (if required) and installation in the ceiling space	**Unsafe noise and vibration levels**	Noise and vibration: hearing protection for blowers and power tools.	Lead installer directly supervises the crew, checks the control before anyone enters the ceiling and again at the start of each day, and stops work if it cannot be followed	TEST Lead Installer (lead installer)
Ceiling insulation removal (if required) and installation in the ceiling space	**Respiratory hazards and irritants (dust, odours)**	Dust and irritants: P2 mask, goggles, gloves and long sleeves in the ceiling; removed material bagged in the ceiling.	Lead installer directly supervises the crew, checks the control before anyone enters the ceiling and again at the start of each day, and stops work if it cannot be followed	TEST Lead Installer (lead installer)
Ceiling insulation removal (if required) and installation in the ceiling space	**Working in enclosed spaces**	Enclosed spaces: exits kept clear, lighting set up first, stay in contact with someone outside the ceiling.	Lead installer directly supervises the crew, checks the control before anyone enters the ceiling and again at the start of each day, and stops work if it cannot be followed	TEST Lead Installer (lead installer)
Ceiling insulation removal (if required) and installation in the ceiling space	**Working at height (inside and outside the ceiling space)**	Height (inside and outside the ceiling space): walk only on joists or crawl boards, never on plasterboard; ladder secured and footed with three points of contact; no roof access in wind or rain.	Lead installer directly supervises the crew, checks the control before anyone enters the ceiling and again at the start of each day, and stops work if it cannot be followed	TEST Lead Installer (lead installer)
Ceiling insulation removal (if required) and installation in the ceiling space	**Fire hazards and ignition sources (flues, chimneys, gas heaters, heat lamps, exhaust fans, downlights, cables over 400 mm surrounded by insulation)**	Fire and ignition sources: AS 3999 clearances kept to flues, chimneys, gas heaters, heat lamps, exhaust fans and downlights; cables over 400 mm in insulation as the PIESA directs.	Lead installer directly supervises the crew, checks the control before anyone enters the ceiling and again at the start of each day, and stops work if it cannot be followed	TEST Lead Installer (lead installer)

How these are put in place: the lead installer directly supervises the crew, checks every control before anyone enters the ceiling and again at the start of each day, and stops work if any control cannot be followed.

Specific to this house
TEST site note: manhole is in the laundry ceiling, low clearance at the eaves on the north side, old foil sarking near the hip — walk only on joists. Owner has a dog; keep the side gate closed. Solar inverter on the garage wall: isolate at the inverter and the switchboard before entry. Gas ducted heater flue in the hallway ceiling: keep the AS 3999 clearance. Extreme heat forecast in the afternoon: work from 6am and stop by noon.

Worker sign-off (I have read the safety plan and will follow it)

Name	Signature (typed name)	Date
TEST Lead Installer (lead installer)	*signed — typed "TEST Lead Installer"*	02/11/2026 7:15pm (Melbourne time)
TEST Crew Member (installer)	*signed — typed "TEST Crew Member"*	03/11/2026 8:40am (Melbourne time)