	decoupling of power stations	
51.5		
Hz	normal state automatic regulation	
50.0		
49.8	alarm, activation of	general pertur-
49.5	reserves tripping of pumps	bation without interruption of
49.0	bbB o. babo	supply
40.7	10-15% cut-off	
48.7	+10-15% cut-off	catastrophal state
48.3	+15-20% cut-off	with regional limitations of
48.1		supply
47.5	+15-20% cut-off	
.,.5	All power station in island operation	Loss of supply
	measures	situation
	7	