INSPECTION SHEET · SS-03 CONSTRUCTION ENVIRONMENTAL MANAGEMENT

Erosion & Sedimentation Control Inspection and Corrective Action Log

Riyadh Marina Tower · Mostadam commercial D+C (2019) · Construction stage · manual pp.41–45

Ref No _____ **Inspection date** _____

Time _____ **Inspected by** _____

No	Description	Yes	No	NA	Notes/Comments/Non-Conformances
1	**Dust control and soil erosion by wind**				
1.1	Are soil stockpiles adequately covered or stabilized				
1.2	Are hauling loads are covered with a screen or moistened during transfer				
1.3	Is housekeeping on the hauling roads is regular and adequate?				
1.4	Is perimeter fencing effective in reducing wind speed causing soil erosion?				
1.5	Is there any damage in perimeter fencing?				
1.6	Is there a dust problem prevailing on the construction site				
2	**Stormwater control measures**				
2.1	Is there any incidence of rain in the last 24 hours?				
2.2	Do you have storm water-control measures in place?				
2.3	Do you have earth bund around the site for the diversion of stormwater entering to your site from the surrounding area?				
2.4	Is it effective during rain?				
2.5	Do you have provision for sedimentation control?				
2.6	Is the stormwater discharge point is protected from siltation?				
2.7	Is there any sedimentation basin for settling storm water prior to discharge into storm waterline?				
2.8	Is there use of silt screen (Geo-textile) in storm water channel inside the site?				
2.9	Is there any damage to silt curtain?				
2.10	Do you allow settling of sediments within the project area?				

No	Description	Yes	No	NA	Notes/Comments/Non-Conformances
2.11	Is it changed regularly in the event of clogging after a rain incidence?				
3	**Dewatering water**				
3.1	Do you have provision for dewatering water to control sedimentation.				
3.2	Is there sedimentation tank for settling of groundwater prior to disposal?				
3.3	Do you have any other measures to control sedimentation and erosion from dewatering water?				
3.4	Do you allow infiltration of dewatering water?				
4	**Housekeeping**				
4.1	Is the project area being tidy and clean?				
4.2	Is proper storage and stacking of material at the staging area?				
4.3	Is waste properly collected and disposed of in a timely manner?				
4.4	Is there safekeeping of hazardous material?				
4.5	Is there any spill or leak at site?				
4.6	Is the concrete washout area being in order and regular maintenance is there?				
4.7	Is there any vehicular maintenance at the site?				

Responses reviewed by Admin on 8 Oct 2026.

Checked & verified by _____

Position: Sustainability Manager

Signature _____

Checked & verified by _____

Position: Environmental Manager

Signature _____

Photographs

No PNG or JPEG files are attached to this credit yet. Photographs uploaded against its required documents will appear here, with their upload date.