MATERIAL REVIEW · SMQ

Material checklist · July 2026

Jeddah Central Oceanarium · products reviewed in July 2026 by their review date, and the material credits at the end of the month.

REVIEWED	A - APPROVED	B - APPROVED AS NOTED	C - REVISE AND RESUBMIT	D - REJECTED
1	0	0	1	0

Material credits at the end of July 2026

Credit part	Target	Forecast (BOQ)	Actual (delivered)	Pending	Change	Products
MW-05 Recycled steel	>= 50%	**90%**	100%	10%	no change	2 of 3 count
MW-05 Recycled aggregates	>= 15%	—	—	—	-	0 of 0 count
MW-05 Certified timber	>= 50%	—	—	—	-	0 of 0 count
HC-11 Low-VOC adhesives, sealants, paints and coatings	>= 95%	—	—	—	-	0 of 1 count
HC-11 Formaldehyde: composite wood and ceilings	>= 100%	—	-	—	-	0 of 0 count
RC-01 Materials made in KSA BOQ material cost not entered: shares are of the products in the app	>= 20% / >= 40%	**90%**	100%	10%	no change	2 of 4 count
MW-04 Non-polluting insulation	>= 100%	—	-	—	-	0 of 0 count

Warnings

Resubmission overdue: Jotafloor Easyflow Primer HS (JCD-OCN-MBL-PRO-MTS-0411-00) - C on 2026-05-05; no resubmission 14 days later (due 2026-05-19)

Certificate expired: Jotafloor Easyflow Primer HS (JCD-OCN-MBL-PRO-MTS-0411-00) - Jotun-VOC-content-test-2022.pdf (issued 2022-03-01) expired 2025-03-01: 1) Data sheet or Test Report for Product VOC Content (g/l) complying w

Certificate expired: Jotafloor Easyflow Primer HS (JCD-OCN-MBL-PRO-MTS-0411-00) - RISE-CDPH-emission-report-O100152.pdf (issued 2023-05-12) expired 2026-05-12: 1) Data sheet or Test Report for Product VOC Content (g/l) complying w

Reviewed in July 2026

Product	Submittal	Rev	Manufacturer	Reviewed	Status

Product	Submittal	Rev	Manufacturer	Reviewed	Status
Epoxy coated rebar — THILAL	JCD-OCN-MBL-PRO-TBE-0001-00	Rev 00	THILAL	2026-07-20	C - Revise and resubmit

Still open from earlier months (C or D, waiting for a resubmission)

Product	Submittal	Rev	Manufacturer	Reviewed	Status
Jotafloor Easyflow Primer HS	JCD-OCN-MBL-PRO-MTS-0411-00	Rev 00	Jotun Saudi Limited	2026-05-05	C - Revise and resubmit