



Ref. Certif. No.

HU-004727

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Low-voltage Fuses for PV system

Name and address of the applicant

Yueqing Xianglang Electric Co., Ltd.
Madaotou, Qiligang, Liushi, Yueqing, Wenzhou, 325604
Zhejiang
P.R. China

Name and address of the manufacturer

Yueqing Xianglang Electric Co., Ltd.
Madaotou, Qiligang, Liushi, Yueqing, Wenzhou, 325604
Zhejiang
P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

Yueqing Xianglang Electric Co., Ltd.
Madaotou, Qiligang, Liushi, Yueqing, Wenzhou, 325604
Zhejiang
P.R. China

Ratings and principal characteristics

Ue:1000V DC;
In:2A,3A,4A,5A,6A,8A,10A,12A,15A,16A,20A,25A,30A,32A
Rated breaking capacity: 20kA; gPV; Size: 10×38

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

WSPV-32

Additional information (if necessary may also be reported on page 2)

Detailed information refer to test report CN2357SS 001.

A sample of the product was tested and found to be in conformity with

IEC 60269-6:2010+A1
IEC 60269-1:2006+A1+A2

As shown in the Test Report Ref. No. which forms part of this Certificate

CN2357SS 001

This CB Test Certificate is issued by the National Certification Body




TÜVRheinland®

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2023-12-18

Signature:


Wencai Zhang



Ref. Certif. No.

HU-004727

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Low-voltage Fuses for PV system

Name and address of the applicant

Yueqing Xianglang Electric Co., Ltd.
Madaotou, Qiligang, Liushi, Yueqing, Wenzhou, 325604
Zhejiang
P.R. China

Name and address of the manufacturer

Yueqing Xianglang Electric Co., Ltd.
Madaotou, Qiligang, Liushi, Yueqing, Wenzhou, 325604
Zhejiang
P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

Yueqing Xianglang Electric Co., Ltd.
Madaotou, Qiligang, Liushi, Yueqing, Wenzhou, 325604
Zhejiang
P.R. China

Ratings and principal characteristics

Ue:1000V DC;
In:2A,3A,4A,5A,6A,8A,10A,12A,15A,16A,20A,25A,30A,32A
Rated breaking capacity: 20kA; gPV; Size: 10×38

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

WSPV-32

Additional information (if necessary may also be reported on page 2)

Detailed information refer to test report CN2357SS 001.

A sample of the product was tested and found to be in conformity with

IEC 60269-6:2010+A1
IEC 60269-1:2006+A1+A2

As shown in the Test Report Ref. No. which forms part of this Certificate

CN2357SS 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2023-12-18

Signature:

Wencai Zhang