



Ref. Certif. No.

HU-004863

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

DC Circuit Breaker

Name and address of the applicant

Yueqing Xianglang Electric Co., Ltd.  
Madaotou, Qiligang, Liushi, Yueqing, Wenzhou, 325604  
Zhejiang  
P.R. China

Name and address of the manufacturer

Yueqing Xianglang Electric Co., Ltd.  
Madaotou, Qiligang, Liushi, Yueqing, Wenzhou, 325604  
Zhejiang  
P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

Yueqing Xianglang Electric Co., Ltd.  
Madaotou, Qiligang, Liushi, Yueqing, Wenzhou, 325604  
Zhejiang  
P.R. China

Ratings and principal characteristics

Selectivity category: A; Inteded for use: DC and PV  
systems; Type of release: Thermo-magnetic; 1P/2P/3P/4P  
appearance; Ue: DC250(1P), DC500(2P), DC750(3P), DC1000(4P);  
In: 6/10/16/20/25/32/40/50/63;  
Ii: 8In(B-type); 10In(C-type); 12In(D-type);  
Icu: 6kA; Ics: 6kA; Ui: 1000V; Uimp: 6kV

Trademark / Brand (if any)

xianglang (logo)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

XL7-63

Additional information (if necessary may also be reported on page 2)

Detailed information refer to test report CN2357SS 001.

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

CN24PZ11 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., MEEI Division  
H-1143 Budapest, Gizella út 51-57., Hungary  
Web: www.tuv.com

Date: 2024-03-15

Signature:

Wencai Zhang