



SAMPLE DOCUMENT · Fictitious data for demonstration only. Not an official inspection record.

STORE

#014 · Miraflores, Lima

PERIOD

1–30 September 2026

GENERATED

1 October 2026, 06:00 (Lima)

MONITORED CIRCUITS

12 sensors · gateway GW-014-A

SAFE-TO-CLEAN CHECKS

30 / 30 passed

GROUND-FAULT ALARMS

1 (18 mA)

TEMPERATURE ALERTS

1

SIGNAL LOSSES

1 (2 min)

Event log (selected entries)

DATE	TIME	EVENT	EQUIPMENT / ZONE	READING	RESULT
2026-09-01	23:38	Safe-to-Clean check	All wet zones	0 mA	Passed
2026-09-04	10:15	Leakage test	Fryer bank	3 mA	Passed
2026-09-08	23:44	Safe-to-Clean check	All wet zones	0 mA	Passed
2026-09-11	10:05	Leakage test	Grill & griddle	2 mA	Passed
2026-09-15	23:40	Safe-to-Clean check	All wet zones	0 mA	Passed
2026-09-18	21:12	Temperature alert	Walk-in cooler	6.8 °C	Warning · INC-2288
2026-09-18	21:40	Work order	Walk-in cooler	—	Technician assigned
2026-09-22	23:39	Sensor signal lost	Ice machine	—	Unmonitored 2 min
2026-09-25	10:10	Leakage test	Fryer bank	4 mA	Passed
2026-09-27	23:41	Ground-fault alarm	Fryer 02	18 mA	Alarm · INC-2291
2026-09-27	23:42	Isolation	Fryer 02	—	Isolated · crew clear
2026-09-28	09:30	Work order WO-1182	Fryer 02	—	Electrician dispatched
2026-09-29	23:43	Safe-to-Clean check	All wet zones	0 mA	Passed
2026-09-30	23:40	Safe-to-Clean check	All wet zones	0 mA	Passed

The full export lists every Safe-to-Clean check, leakage test and alarm of the period with its timestamp and the operator who acknowledged it.