

INDEX OF DRAWINGS						
Sheet Number	SHEET NAME	CUP-SD - 10/01/2024	OWNER REVIEW - 02/27/2025	CUP-PERMIT ISSUANCE_4/7	CUP- BULLETIN 07 - 12/22/2025	CUP- BULLETIN 10 - 04/03/2026
ARCHITECTURAL						
UA0.00	COVER SHEET	X	X	X		
UA0.01	INDEX OF DRAWINGS	X	X	X	X	X
UA0.02	PROJECT INFORMATION	X	X	X		
UALS.01	LIFE SAFETY PLANS - LEVEL 01 & 02	X	X	X	X	
UA01.11	DEMOLITION PLAN - LEVEL 01	X	X	X		
UA01.12	DEMOLITION PLAN - ROOF	X	X	X		
UA01.13	DEMOLITION PLAN - ELEVATION	X	X	X		
UA01.14	DEMOLITION PLAN - SECTIONS	X	X	X		
UA1.02	ARCHITECTURAL STREET LEVEL	X	X	X		
UA1.04	ROOF PH - CUP UTILITY	X	X	X	X	X
UA1.11	FLOOR PLAN - LEVEL 01	X	X	X	X	
UA1.12	FLOOR PLAN - LEVEL 02	X	X	X	X	
UA1.13	FLOOR PLAN - ROOF	X	X	X	X	X
UA1.14	FLOOR PLAN - ROBERT BUILDING	X	X	X	X	X
UA4.01	REFLECTED CEILING PLAN - LEVEL 01	X		X	X	
UA4.02	REFLECTED CEILING PLAN - LEVEL 02	X		X	X	
UA5.01	ELEVATIONS	X	X	X	X	
UA5.02	ELEVATIONS	X	X	X	X	X
UA5.03	ELEVATIONS	X	X	X	X	
UA6.01	BUILDING SECTIONS	X	X	X	X	X
UA6.10	WALL SECTIONS	X	X	X	X	
UA6.11	WALL SECTIONS	X	X	X	X	X
UA6.12	WALL SECTIONS	X	X	X	X	
UA7.01	DETAILS	X	X	X	X	
UA7.02	DETAILS	X	X	X	X	
UA7.03	DETAILS	X	X	X	X	X
UA7.04	DETAILS	X	X	X	X	
UA7.05	DETAILS	X	X	X	X	
UA7.06	DOOR AND METAL WALL PANEL DETAILS	X	X	X	X	X
UA7.07	STAIR DETAILS	X	X	X	X	
UA7.08	ROOFING DETAILS	X	X	X	X	
UA7.09	DIRECT BOND PLASTER DETAILS & PARTITION TYPES	X	X	X	X	
UA7.10	PLAN DETAILS			X	X	
UA7.11	CONDUIT DETAILS				X	X
UA8.01	STAIR PLANS AND SECTIONS		X	X	X	
STRUCTURAL						
US-000	COVER SHEET	X	X	X	X	
US-001	GENERAL NOTES	X	X	X	X	
US-002	SCHEDULES	X	X	X	X	
US-003	SPECIAL INSPECTIONS	X	X	X	X	
US-101	FOUNDATION (LEVEL 01) PLAN	X	X	X	X	
US-102	LEVEL 02 FRAMING PLAN	X	X	X	X	
US-103	ROOF FRAMING PLAN	X	X	X	X	
US-104	FRAMING ELEVATIONS	X	X	X	X	
US-200	TYPICAL FOUNDATION DETAILS	X	X	X	X	
US-201	TYPICAL CONCRETE DETAILS	X	X	X	X	
US-202	FOUNDATION SECTIONS	X	X	X	X	
US-300	TYPICAL FRAMING DETAILS	X	X	X	X	
US-301	FRAMING SECTIONS	X	X	X	X	
US-302	FRAMING SECTIONS	X	X	X	X	
US-501	PARTIAL ROBERTS LEVEL 01-03 AND CUP ROOF FRAMING PLANS					X
US-502	PARTIAL ROBERTS LEVEL 04 FRAMING PLAN					X
US-510	PIPE RACK ELEVATIONS AND SECTIONS					X
MECHANICAL						
UM-002	SCOPE OF WORK MATRIX	X		X		
UMD-100	BOILER BUILDING - DUCTWORK DEMOLITION PLAN		X	X		
UMD-101	BOILER BUILDING - PIPING DEMOLITION PLAN		X	X		
UMD-102	BUILDING BUILDING - ROOF DEMOLITION PLAN		X	X		
UMD-103	BUILDING BUILDING - COMPRESSED AIR DEMOLITION PLAN		X	X		
UMD-104	DORRANCE BUILDING - COMPRESSED DEMOLITION PLANS/SCHEMATIC		X	X		
UMD-105	STEAM FLOW SCHEMATIC - DEMOLITION		X	X		
UMD-106	BOILER BLDG - DOMESTIC COLD WATER SCHEMATIC - DEMOLITION		X	X		
UMD-200	BUILDING 85 - LEVEL 01 & LEVEL 02 - DEMOLITION PLAN		X	X		
UMD-201	BUILDING 85 - ROOF - DEMOLITION PLAN		X	X		
UMD-202	ROBERTS BASEMENT MECHANICAL ROOM - DEMOLITION PLAN		X	X		
UM-000	MECHANICAL LEGEND		X	X		
UM-003	MECHANICAL SCHEDULES	X		X		X
UM-004	MECHANICAL SCHEDULES	X		X		
UM-100	BOILER BUILDING - DUCTWORK PLAN - LEVEL 01		X	X		
UM-101	BOILER BUILDING - PIPING PLAN - LEVEL 01		X	X		X
UM-102	BOILER BUILDING - NEW ROOF WORK - PLAN		X	X		
UM-103	BOILER BUILDING - COMPRESSED AIR PLAN		X	X		
UM-104	DORRANCE BUILDING - COMPRESSED RENOVATION PLAN/ SCHEMATIC		X	X		
UM-105	STEAM FLOW SCHEMATIC - NEW WORK		X	X		
UM-106	BOILER BLDG - DOMESTIC COLD WATER SCHEMATIC - NEW WORK		X	X		
UM-107	BOILER ROOM SECTION VIEW - NEW WORK		X	X		
UM-108	BOILER BUILDING - NATURAL GAS PIPING PLAN		X	X		
UM-109	BOILER FEEDWATER SCHEMATICS - DEMOLITION & NEW WORK		X	X		
UM-110	MECH. COMBUSTION AIRFLOW SCHEMATICS DEMOLITION & NEW WORK		X	X		
UM-111	PIPING SCHEMATICS DEMOLITION & NEW WORK		X	X		
UM-112	BOILER BUILDING - RIGGING PLAN - LEVEL 1 - 800 HP		X	X		
UM-113	BOILER BUILDING - ELEVATION VIEW - NEW WORK		X	X		
UM-117	DUCTWORK PLAN - CUP LEVEL 02		X	X	X	
UM-200	BUILDING 85 - LEVEL 01 & LEVEL 02 - PIPING PLAN		X	X		X
UM-201	BUILDING 85 - ROOF - PIPING PLAN		X	X		
UM-202	ROBERTS BASEMENT MECHANICAL ROOM - PIPING PLAN		X	X		
UM-203	CHILLED WATER MASTER PLAN SCHEMATICS		X	X		
UM-204	CHILLED WATER PIPING OVER ROOF		X	X		X
UM-205	CHILLER TO COOLING TOWER PIPING SCHEMATIC		X	X		
UM-206	CHILLED WATER THROUGH LOBBY TO BASEMENT LEVEL		X	X		X
UM-210	MECHANICAL PIPING PLAN - CUP LEVEL 01	X		X		X
UM-211	MECHANICAL PIPING PLAN - CUP LEVEL 02	X		X	X	
UM-212	T-A MECHANICAL PIPING PLAN - CUP BASEMENT	X		X	X	
UM-213	T-A MECHANICAL PIPING PLAN - CUP LEVEL 02	X		X	X	
UM-214	T-A MECHANICAL PIPING PLAN - CUP LEVEL 02 BRIDGE	X		X		
UM-216	FUEL OIL FLOW DIAGRAM	X		X		
UM-217	HIGH AND MEDIUM PRESSURE STEAM RISER	X		X		X
UM-300	MECHANICAL DETAILS		X	X		
UM-301	MECHANICAL DETAILS		X	X		
UM-302	MECHANICAL DETAILS		X	X		
UM-303	MECHANICAL DETAILS		X	X		
UM-304	MECHANICAL DETAILS		X	X		
UM-305	MECHANICAL DETAILS		X	X		
UM-306	SEISMIC DETAILS		X	X		
UM-307	SEISMIC DETAILS		X	X		
UM-308	BOILER STACKS SECTION VIEWS		X	X		
UM-400	MECHANICAL SCHEDULES		X	X		
UM-401	MECHANICAL SCHEDULES		X	X		
UM-217	HIGH AND MEDIUM PRESSURE STEAM RISER DIAGRAM					
PLUMBING						
UP-104	CUP EXPANSION PLANS		X	X	X	
PLUMBING						
UP-000	PLUMBING LEGEND			X		
UP-100	BUILDING 85 - FLOOR AND ROOF PLANS - NEW WORK		X	X		
UP-101	BUILDING 85 - FLOOR AND ROOF PLANS - DEMOLITION		X	X		
UP-101	BUILDING 85 - LEVEL 01 PLAN		X	X		X
UP-102	DORRANCE & ROBERTS PAVILION - BASEMENT PLAN		X	X		X
UP-103	BUILDING 85 - LEVEL 01 PLAN		X	X		X
UP-105	CAMPUS - BASEMENT PIPE ROUTING PLAN		X	X		X
UP-200	DETAILS		X	X		X
ELECTRICAL						
UE-001	ENERGY COMPLIANCE SHEET					
UE-001	CUP EXPANSION - ELECTRICAL SYMBOLS LEGEND	X	X	X		
UE-002	CUP EXPANSION - ELECTRICAL SCHEDULES	X		X		
UED-101	BOILER BUILDING ELECTRICAL DEMOLITION PLAN	X	X	X		
UED-102	BUILDING 06 ELECTRICAL DEMOLITION PLAN	X	X	X		
UED-103	ROOF ELECTRICAL DEMOLITION PLAN	X	X	X		
UE-101	BOILER BUILDING ELECTRICAL RENOVATION PLAN	X	X	X		X
UE-102	BUILDING 06 ELECTRICAL RENOVATION PLAN	X	X	X		
UE-103	ROOF ELECTRICAL RENOVATION PLAN	X	X	X		
UE-104	DORRANCE BUILDING COMPRESSED AIR PLAN	X	X	X		
UE-111	CUP EXPANSION - ELECTRICAL POWER PLAN	X	X	X		
UE-121	CUP EXPANSION - ELECTRICAL LIGHTING PLAN	X	X	X		
UE-131	CUP EXPANSION - ELECTRICAL CONDUIT PLAN	X	X	X		
UE-201	ONLINE DIAGRAM - NORMAL POWER	X	X	X		X
UE-202	ONLINE DIAGRAM - EXISTING GHP	X	X	X		
UE-203	ONLINE DIAGRAM - EMERGENCY POWER	X	X	X		
UE-204	ONLINE DIAGRAM - EXISTING PRIMARY NORMAL POWER	X	X	X		
UE-205	CUP EXPANSION - ESSENTIAL POWER DIAGRAM	X	X	X		
UE-301	PANEL SCHEDULES	X	X	X		
UE-302	CUP EXPANSION - ELECTRICAL PANEL SCHEDULES	X	X	X		
UE-401	ELECTRICAL SEISMIC DETAILS	X	X	X		
UE-402	CUP EXPANSION - ELECTRICAL DETAILS	X	X	X		
UE-403	CUP EXPANSION - ELECTRICAL DETAILS	X	X	X		
UE-502	CUP EXPANSION - ELECTRICAL SECTION VIEWS		X	X		
FIRE ALARM						
UFA-001	CUP EXPANSION - FIRE ALARM LEGEND	X	X	X		
UFA-111	CUP EXPANSION - FIRE ALARM PLAN	X		X		
UFA-200	CUP EXPANSION - FIRE ALARM RISER DIAGRAM		X	X		
FIRE PROTECTION						
UPF0-00	FIRE PROTECTION LEGEND		X	X		
UPF1-01	CUP EXPANSION - FIRE PROTECTION PLAN - LEVEL 01		X	X	X	
UPF1-02	CUP EXPANSION - FIRE PROTECTION PLAN - LEVEL 2		X	X		
UPF2-01	FIRE PROTECTION DETAILS		X	X		
UPF3-01	FIRE PROTECTION RISER DIAGRAM		X	X		
800						

RESERVE FOR DCA STAMP

HKS

ARCHITECT

HKS, P.C.
1250 I (EYE) STREET NW, SUITE 600
WASHINGTON, DC 20005

STRUCTURAL ENGINEER

ODONWELL & MACCARATO
701 MARKET ST. #600
PHILADELPHIA, PA 19106

MEP-FP / LOW VOLTAGE ENGINEER

BR-A CONSULTING ENGINEERS
2401 WALNUT ST SUITE 701
PHILADELPHIA, PA 19103

HIGHLAND ASSOCIATES

102 HIGHLAND AVE
CLARKS SUMMIT, PA 18411

Cooper

University Health Care

COOPER UNIVERSITY

HOSPITAL - CUP EXT

PROJECT ADDRESS: 1 COOPER PLAZA, CAMDEN, NJ 08103

OWNER

COOPER UNIVERSITY HEALTHCARE
1 COOPER PLAZA
CAMDEN, NJ 08103

PROJECT MANAGER

PURE PM
2926 RICHMOND STREET
PHILADELPHIA, PA 19134

CIVIL ENGINEER

LANGAN
1818 MARKET STREET, SUITE 3800
PHILADELPHIA, PA 19103

SEAL & SINGATURE

KEY PLAN

REVISION

NO.	DESCRIPTION	DATE
1	RFI #423	11/17/25
2	BULLETIN 07	12/22/25
3	BULLETIN 10	04/03/26

HKS PROJECT NUMBER

25695.150

DATE

04/07/2025

ISSUE

ISSUED FOR PERMIT


SHEET TITLE

INDEX OF DRAWINGS

SHEET NO.

UA0.01

PRINT DATE: 03/20/26 4:48:28 PM TEMPLATE VERSION: 23.3.3 MODEL: Alameda Docs (25695.150) Cooper Medical Campus Plan 2025A_CUP_CUP 2025.rvt TITLE BLOCK VERSION: 2010B30



01 LEVEL PH ROOF_CUP_Utility
1" = 20'-0"

RESERVE FOR DCA STAMP


HKS

ARCHITECT
HKS, P.C.
1250 I (EYE) STREET NW, SUITE 600
WASHINGTON, DC 20005
STRUCTURAL ENGINEER
ODONWELL & MACCARATO
701 MARKET ST. #600
PHILADELPHIA, PA 19106
MEP-FP / LOW VOLTAGE ENGINEER
BR-A CONSULTING ENGINEERS
2401 WALNUT ST SUITE 701
PHILADELPHIA, PA 19103
HIGHLAND ASSOCIATES
102 HIGHLAND AVE
CLARKS SUMMIT, PA 18411

Cooper University Health Care
COOPER UNIVERSITY HOSPITAL - CUP EXT
PROJECT ADDRESS: 1 COOPER PLAZA, CAMDEN, NJ 08103

OWNER
COOPER UNIVERSITY HEALTHCARE
1 COOPER PLAZA
CAMDEN, NJ 08103
PROJECT MANAGER
PURE PM
2026 RICHMOND STREET
PHILADELPHIA, PA 19134
CIVIL ENGINEER
LANGAN
1818 MARKET STREET, SUITE 3800
PHILADELPHIA, PA 19103
SEAL & SIGNATURE

KEY PLAN



REVISION	NO.	DESCRIPTION	DATE
1	BULLETIN 10		04/03/26

HKS PROJECT NUMBER
25695.150
DATE
04/07/2025
ISSUE
ISSUED FOR OWNER REVIEW
SHEET TITLE
ROOF PH - CUP UTILITY

SHEET NO.

UA1.04


BUILDING PERMIT NUMBER: 1111

© HKS, INC.

TITLE BLOCK VERSION: 20210830
MODEL: Autodesk Docs:25695.000_Cooper Master Campus Plan 2023A_CUP-CUP 2025.rvt
PRINT DATE: 03/20/25 4:48:31 PM
TEMPLATE VERSION: 23.0.3

01 FLOOR PLAN - ROOF

1/8" = 1'-0"



RESERVE FOR DCA STAMP


HKS

ARCHITECT
HKS, P.C.
1250 I (EYE) STREET NW, SUITE 600
WASHINGTON, DC 20005
STRUCTURAL ENGINEER
ODONWELL & MACCARATO
701 MARKET ST. #200
PHILADELPHIA, PA 19106
MEP-FP / LOW VOLTAGE ENGINEER
BR-A CONSULTING ENGINEERS
2401 WALNUT ST SUITE 701
PHILADELPHIA, PA 19103
HIGHLAND ASSOCIATES
102 HIGHLAND AVE
CLARKS SUMMIT, PA 18411

Cooper University Health Care
COOPER UNIVERSITY HOSPITAL - CUP EXT
PROJECT ADDRESS: 1 COOPER PLAZA, CAMDEN, NJ 08103

OWNER
COOPER UNIVERSITY HEALTHCARE
1 COOPER PLAZA
CAMDEN, NJ 08103
PROJECT MANAGER
PURE PM
2026 RICHMOND STREET
PHILADELPHIA, PA 19134
CIVIL ENGINEER
LANGAN
1818 MARKET STREET, SUITE 3800
PHILADELPHIA, PA 19103
SEAL & SIGNATURE

KEY PLAN



REVISION	NO.	DESCRIPTION	DATE
1	RFI #248		06/19/25
2	RFI #473		12/12/25
3	BULLETIN 07		12/22/25
4	BULLETIN 10		04/03/26

HKS PROJECT NUMBER
25695.150

DATE
04/07/2025


ISSUE
ISSUED FOR OWNER REVIEW
SHEET TITLE
FLOOR PLAN - ROOF

SHEET NO.

UA1.13

BUILDING PERMIT NUMBER: 1111

© HKS, INC.



04 CUP UTILITY DETAIL AT ROBERT BUILDING - LEVEL 04

03 FLOOR PLAN - ROBERT PAVILION - LEVEL 02

02 FLOOR PLAN - ROBERT PAVILION - LEVEL 01

01 REFLECTED CEILING PLAN - ROBERT PAVILION BASEMENT

 ASHE ICRA 2.0™
Matrix of Precautions for Construction, Renovation and Operations

Step One:
Using Table 1, Identify the Activity Type (A-D).

Table 1 - Activity Type: Type C	
	Inspection and non-invasive activities, includes but is not limited to: - Removal of coating for live visual inspection, limited to 1 dip per 50 square feet with limited excavation - Unlimited plumbing system maintenance (e.g., pneumatic tube station, HVAC system, live suppression system, electrical and capacity work to include draining without sending) that does not create dust or debris - Clean plumbing activity limited in nature
Type A	Small-scale, short duration activities that create minimal dust and debris, includes but is not limited to: - Work conducted above the ceiling (e.g., prolonged inspection of interior of trawlers and trawler, installation of electrical panel, and access to mechanical and/or electrical space spaces) - Fin chiseling - Installation of suction pipe or flow tracing. This produces minimal dust and debris. - The removal of drywall where minimal dust and debris is created - Controlled sanding activities (e.g., wet or dry sanding) that produce minimal dust and debris
Type B	Large-scale, longer duration activities that create a moderate amount of dust and debris, includes but is not limited to: Removal of preexisting floor covering, walls, ceiling or other building components
Type C	- New drywall placement - Renovation work in a single room - Non-existing cable pathway or invasive electrical work above ceilings. - The removal of drywall where a moderate amount of dust and debris is created. - Dry sanding where a moderate amount of dust and debris is created. - Work creating significant vibration and/or noise. - Any activity that cannot be completed in a single work shift.
	Major demolition and construction activities, includes but is not limited to:
Type D	- Removal or replacement of building system components) - Removal/participation of demolition activities - Installation of new building construction - Reinforce large-scale new building construction - Reinforce work in two or more rooms

Step Two:
Using Table 2, identify the Patient Risk Group(s) that will be affected. If more than one risk group will be affected, select the higher risk group.

Table 2 - Patient Risk Group: Low Risk

Low-risk	Medium Risk	High Risk	Highest Risk
No patient care areas such as: • Public hallways and gathering areas not on clinical units. • Office areas not on clinical units. • Breakrooms not on clinical units. • Bathrooms or locker rooms not on clinical units. • Mechanical rooms not on clinical units. • EVS closets not on clinical units.	Patient care support areas such as: • Waiting areas • Casual engineering • Materials management • Sterile processing department - dirty side • Kitchen/canteen, cafeteria, staff food area, and food lockers	Patient care areas such as: • Patient rest rooms and other • All day-care areas • Emergency • Outpatient surgery • Employee health center • General work zone • Medical rooms and clean utility rooms • Imaging areas • Diagnostic imaging Laboratory	Procedural, invasive, sterile support and highly compromised patient care areas such as: • All intensive and intensive surgical • All oncology units • OB theaters and resuscitation • Procedure suites • Endoscopy • Sterilization services • Sterile processing department • Transfusion services • Dedicated isolation • Ventilation • Imaging suites (invasive)

Step Three:
Match the Patient Risk Group (*Low, Medium, High, Highest*) from Step Two with the planned Constructive Activity Project Type (*A, B, C, D*) from Step One using Table 3 to find the Class of Precautions (*I, II, III, IV*) or level of infection control activities required. The activities are listed in Table 5 – Minimum Required Infection Control Precautions by Class.

Table 3 - Class of Precautions: **Class II**

Patient Risk Group	Project Type			
	TYPE A	TYPE B	TYPE C	TYPE D
LOW Risk Group	I	II	II	III*
MEDIUM Risk Group	I	II	III*	IV
HIGH Risk Group	I	III	IV	V
HIGHEST Risk Group	III	IV	V	V

Environmental conditions that could affect human health, such as sewage, mold, asbestos, gray water and black water will require Class of Precautions IV for LOW and MEDIUM Risk Groups and Class of Precautions V for HIGH and HIGHEST Risk Groups.

*Type C [Medium Risk groups] and Type D [Low Risk Groups] work areas [Class III precautions] that cannot be sealed and completely isolated from occupied patient care spaces should be elevated to include negative air exhaust requirements as listed in Class IV Precautions.

Table 5 - Minimum Required Infection Control Precautions by Class | Before and During Work Activity

[illegible][illegible]

Table 6 - Minimum Required Infection Control Precautions | Upon Completion of Work Activity

Classifications	Mitigation Activities (Performed upon Completion of Work Activity)
Classes I, II, III and IV	i. Clean work areas including all environmental surfaces, high horizontal surfaces and flooring materials. ii. Check if supply and return air registers for dust accumulation on upper surfaces as well as on diffuser surfaces. HVAC Systems: i. Remove isolation of HVAC system in areas where work is being performed. Verify that HVAC systems are clean and operational. ii. Verify the HVAC systems meet original airflow and air exchange design specifications. Class II Type A Activities only: i and V precautions require inspection and documentation for compromised Class II Type A activities. Construction areas must be inspected by an infection preventionist to diagnose and engineering consultation for decontamination or downgrading of ICRA precautions. Work Area Cleaning i. Clean work areas including all environmental surfaces, high horizontal surfaces and flooring materials. ii. Check if supply and return air registers for dust accumulation on upper surfaces as well as on diffuser surfaces. Removal of Critical Barriers: i. Critical barriers must remain in place during all work involving dirty removal; creation of dusts or aerosols or other hazardous activities/work. The barrier may NOT be removed until all work is completed and cleaning has been performed. ii. As a guideline to prevent barrier removal activities, must be completed to a measure that prevents dust release. Use the following precautions when removing hard barriers: a. Carefully remove barriers and sealant. b. If it will be generated under screw removal, use hand-held HEPA vacuum. c. Drywall cutting is prohibited during removal process. d. Color of dust from base wall with HEPA vacuum before removing soft lead barrier. e. Use a plastic bucket to enclose area if dust could be generated. Negative Air Requirements: i. Use of negative air flow must be designed to remove contaminants from the work zone. ii. Negative air devices must remain operational at all times and in place for a period after completion of dust creating activities to remove contaminants from the work area and before removal of critical barriers. HVAC Systems: i. Upon removal of critical barriers, remove isolation of HVAC system in areas where work is being performed. ii. Verify that HVAC systems are clean and operational. iii. Verify the HVAC systems meet original airflow and air exchange design specifications.
Class IV and V	

©2022 The American Society for Health Care Engineering of the American Hospital Association Disclaimer. This document is provided by ASHE as a service to its members. The information provided may not apply to a reader's specific situation and is not a substitute for application of the reader's own independent judgment or the advice of a competent professional. ASHE does not make any guaranty or warranty as to the accuracy or completeness of any information contained in this document. ASHE and the authors disclaim liability for personal injury, property damage, or other damages of any kind, whether special, indirect, consequential, or compensatory, that may result directly or indirectly from use of or reliance on this document.

RESERVE FOR DCA STAMP

HKS

ARCHITECT
HKS, P.C.
1250 I (EYE) STREET NW, SUITE 600
WASHINGTON, DC 20005

STRUCTURAL ENGINEER
O'DONNELL & NACCARATO
701 MARKET ST. #6000
PHILADELPHIA, PA 19106

**MEP-FP / LOW VOLTAGE
ENGINEER**
BR+A CONSULTING ENGINEERS
2401 WALNUT ST SUITE 701
PHILADELPHIA, PA 19103
HIGHLAND ASSOCIATES
102 HIGHLAND AVE
CLARKS SUMMIT, PA 18411

Cooper
University Health Care

**COOPER UNIVERSITY
HOSPITAL - CUP EXT**


OWNER
COOPER UNIVERSITY HEALTHCARE
1 COOPER PLAZA
CAMDEN, NJ 08103

PROJECT MANAGER
PURE PM
2926 RICHMOND STREET
PHILADELPHIA, PA 19134

CIVIL ENGINEER
LANGAN
1818 MARKET STREET, SUITE 3800
PHILADELPHIA, PA 19103

SEAL & SINGATURE

KEY PLAN



REVISION		
NO.	DESCRIPTION	DATE
1	BULLETIN 10	04/03/26

HKS PROJECT NUMBER
25695.150




DATE
04/07/2025
ISSUE

ISSUE
**ISSUED FOR OWNER
REVIEW**
SHEET TITLE
**FLOOR PLAN - ROBERT
BUILDING**

SHEET NO. 1

UA1.14

TITLE BLOCK VERSION: 20210830
MODEL: AutoCAD Dwg 25695.000 Cooper Master Campus Plan 2023A CH-CUP 2023.rvt
PRINT DATE: 03/20/2024 4:46 PM TEMPLATE VERSION: 23.0.3
© HKS, INC.



RESERVE FOR DCA STAMP


HKS

ARCHITECT
HKS, P.C.
1250 I (EYE) STREET NW, SUITE 600
WASHINGTON, DC 20005
STRUCTURAL ENGINEER
ODONWELL & MACCARATO
701 MARKET ST. #600
PHILADELPHIA, PA 19106
MEP-FP / LOW VOLTAGE ENGINEER
BR-A CONSULTING ENGINEERS
2401 WALNUT ST SUITE 701
PHILADELPHIA, PA 19103
HIGHLAND ASSOCIATES
102 HIGHLAND AVE
CLARKS SUMMIT, PA 18411

Cooper University Health Care
COOPER UNIVERSITY HOSPITAL - CUP EXT
PROJECT ADDRESS: 1 COOPER PLAZA, CAMDEN, NJ 08103

OWNER
COOPER UNIVERSITY HEALTHCARE
1 COOPER PLAZA
CAMDEN, NJ 08103
PROJECT MANAGER
PURE PM
2026 RICHMOND STREET
PHILADELPHIA, PA 19134
CIVIL ENGINEER
LANGAN
1818 MARKET STREET, SUITE 3800
PHILADELPHIA, PA 19103
SEAL & SIGNATURE

KEY PLAN



REVISION	NO.	DESCRIPTION	DATE
1	BULLETIN 07		12/22/25
2	BULLETIN 10		04/03/26








HKS PROJECT NUMBER
25695.150
DATE
04/07/2025
ISSUE
ISSUED FOR PERMIT

SHEET TITLE
BUILDING SECTIONS

SHEET NO.

UA6.01

PRINT DATE: 03/20/2024 4:48:53 PM TEMPLATE VERSION: 23.0.3 MODEL: A:\models\Drawings\25695.00_Cooper_Medical_Campus_Plan_2023.dwg CUP-CUP_2023.rvt TITLE BLOCK VERSION: 20210830




RESERVE FOR DCA STAMP

HKS

ARCHITECT
HKS, P.C.
1250 I EYE STREET NW, SUITE 600
WASHINGTON, DC 20005
STRUCTURAL ENGINEER
ODONWELL & MACCARATO
701 MARKET ST. #600
PHILADELPHIA, PA 19106
MEP-FP / LOW VOLTAGE ENGINEER
BR-A CONSULTING ENGINEERS
2401 WALNUT ST SUITE 701
PHILADELPHIA, PA 19103
HIGHLAND ASSOCIATES
102 HIGHLAND AVE
CLARKS SUMMIT, PA 18411

Cooper University Health Care
COOPER UNIVERSITY HOSPITAL - CUP EXT

OWNER
COOPER UNIVERSITY HEALTHCARE
1 COOPER PLAZA
CAMDEN, NJ 08103
PROJECT MANAGER
PURE PM
2026 RICHMOND STREET
PHILADELPHIA, PA 19134
CIVIL ENGINEER
LANGAN
1818 MARKET STREET, SUITE 3800
PHILADELPHIA, PA 19103
SEAL & SIGNATURE



REVISION	NO.	DESCRIPTION	DATE
1	BULLETIN 10		04/03/2024

HKS PROJECT NUMBER
25695.150
DATE
04/07/2025
ISSUE
ISSUED FOR PERMIT

SHEET TITLE
WALL SECTIONS




SHEET NO.

UA6.11

BUILDING PERMIT NUMBER: 1111

© HKS, INC.

TITLE BLOCK VERSION: 20210830
MODEL: Autodesk Docs (25695.150) Cooper Medical Campus Plan 2023A CHA-CUP 2023.rvt
PRINT DATE: 03/20/2024 4:00 PM TEMPLATE VERSION: 23.1.3



RESERVE FOR DCA STAMP

HKS

ARCHITECT

HKS, P.C.
1250 I (EYE) STREET NW, SUITE 600
WASHINGTON, DC 20005

STRUCTURAL ENGINEER

ODONWELL & MACCARATO
701 MARKET ST. #800
PHILADELPHIA, PA 19106

MEP-FP / LOW VOLTAGE ENGINEER

BR-A CONSULTING ENGINEERS
2401 WALNUT ST SUITE 701
PHILADELPHIA, PA 19103
HIGHLAND ASSOCIATES
102 HIGHLAND AVE
CLARKS SUMMIT, PA 18411

Cooper

University Health Care

COOPER UNIVERSITY

HOSPITAL - CUP EXT

OWNER

COOPER UNIVERSITY HEALTHCARE
1 COOPER PLAZA
CAMDEN, NJ 08103

PROJECT MANAGER

PURE PM
2026 RICHMOND STREET
PHILADELPHIA, PA 19134

CIVIL ENGINEER

LANGAN
1818 MARKET STREET, SUITE 3800
PHILADELPHIA, PA 19103

SEAL & SIGNATURE

KEY PLAN

REVISION

NO.	DESCRIPTION	DATE
1	BULLETIN 07	12/22/25
2	BULLETIN 10	04/03/26

HKS PROJECT NUMBER

25695.150

DATE

04/07/2025

ISSUE

ISSUED FOR PERMIT

SHEET TITLE


DETAILS

SHEET NO.


UA7.03

BUILDING PERMIT NUMBER: 1111


HKS, INC.




07 CUP UTILITY - ROOF MOUNTED PIPE SUPPORT SYSTEM
1" = 1'-0"




05 CUP UTILITY AT EXISTING ROBERT DUNNAGE
1" = 1'-0"




03 PLAN DETAIL - CUP UTILITY BRIDGE AT ROBERT BUILDING - LEVEL 1
1" = 1'-0"




06 FURR DOWN DETAIL
1 1/2" = 1'-0"



04 FURR DOWN DETAIL
1 1/2" = 1'-0"



02 STAIR SECTION - NS SECTION
1 1/2" = 1'-0"




01 DETAIL @ GENERATOR- WEST LOUVER BASE
1 1/2" = 1'-0"

HKS

ARCHITECT
HKS, P.C.
1250 I (EYE) STREET NW, SUITE 600
WASHINGTON, DC 20005
STRUCTURAL ENGINEER
ODONWELL & NACCARATO
701 MARKET ST. #6000
PHILADELPHIA, PA 19106
MEP-FP / LOW VOLTAGE ENGINEER
BR-A CONSULTING ENGINEERS
2401 WALNUT ST SUITE 701
PHILADELPHIA, PA 19103
HIGHLAND ASSOCIATES
102 HIGHLAND AVE
CLARKS SUMMIT, PA 18411

Cooper University Health Care
COOPER UNIVERSITY HOSPITAL - CUP EXT
PROJECT ADDRESS: 1 COOPER PLAZA, CAMDEN, NJ 08103

OWNER
COOPER UNIVERSITY HEALTHCARE
1 COOPER PLAZA
CAMDEN, NJ 08103
PROJECT MANAGER
PURE PM
2026 RICHMOND STREET
PHILADELPHIA, PA 19134
CIVIL ENGINEER
LANGAN
1818 MARKET STREET, SUITE 3800
PHILADELPHIA, PA 19103
SEAL & SINGATURE



REVISION	NO.	DESCRIPTION	DATE
1	BULLETIN 07		12/22/25
2	BULLETIN 10		04/03/26

HKS PROJECT NUMBER
25695.150
DATE
04/07/2025
ISSUE
ISSUED FOR PERMIT

SHEET TITLE
DETAILS

SHEET NO.
UA7.05

TYPE "B"

FLOOR PLAN DESIGNATION NO SOUND ATTENUATION	FLOOR PLAN DESIGNATION WITH SOUND ATTENUATION	STUD SIZE	PART WIDTH	FIRE RATING	UL LISTING	STC: NO SOUND WITH SOUND	LABORATORY TEST REPORT & REMARKS
B3	B3	3 5/8"	6 1/8"	NON- RATED	N/A	48 51 (W/ 3 1/2" SAB)	USG - 161222
B6	B6	6"	8 1/2"	NON- RATED	N/A	50 52 (W/ 6" SAB)	
B2	B2	2 1/2"	5"	TWO HOUR	U411	48 49 (W/ 2 1/2" SAB)	
B3	B3	3 5/8"	6 1/8"	TWO HOUR	U411	48 51 (W/ 3 1/2" SAB)	USG - 161222
B6	B6	6"	8 1/2"	TWO HOUR	U411	50 52 (W/ 6" SAB)	
B2	B2	2 1/2"	5"	TWO HOUR/ SMOKE RESIST	U411	48 49 (W/ 2 1/2" SAB)	
B3	B3	3 5/8"	6 1/8"	TWO HOUR/ SMOKE RESIST	U411	48 51 (W/ 3 1/2" SAB)	USG - 161222
B6	B6	6"	8 1/2"	TWO HOUR/ SMOKE RESIST	U411	50 52 (W/ 6" SAB)	


NOTES


- PARTITIONS ARE DISTINGUISHED ON FLOOR PLANS BY SYMBOL DESIGNATION, GRAPHIC DESIGNATION OR A COMBINATION OF BOTH DESIGNATIONS.
- THERE ARE TWO TYPES OF SYMBOL DESIGNATIONS. ONE FOR PARTITIONS NOT REQUIRING SOUND ATTENUATION AND ANOTHER FOR PARTITIONS WHICH REQUIRE SOUND ATTENUATION. REFER TO PARTITION MATRICES FOR SOUND ATTENUATION BLANKET (SAB) MINIMUM THICKNESS FOR STC INDICATED.

XXXX	#	SYMBOL DESIGNATIONS (NO SOUND ATTENUATION)	XXXX	#	SYMBOL DESIGNATION (WITH SOUND ATTENUATION)
------	---	--	------	---	---
- THERE ARE TWO SYMBOL DESIGNATION SYSTEMS USED. THE FIRST SYSTEM CONSISTS OF TWO AND THREE CHARACTERS. THE FIRST CHARACTER IS A LETTER INDICATING THE PARTITION TYPE. THE SECOND CHARACTER IS NUMERIC INDICATING THE STUD OR CMU WIDTH. REFER TO LEGEND BELOW. THIS SYSTEM IS USED TO DEFINE WALL TYPES: A, B, C, D, E, F, H, J, K, M, R.

NUMERIC CHARACTER	STUD WIDTH	CMU WIDTH
1	1 5/8"	
2	2 1/2"	
3	3 5/8"	
4	4"	3 5/8"
5	5"	5 5/8"
6	6"	7 5/8"
12		11 5/8"
- THE # CHARACTER BELOW THE LINE INDICATES THE HEIGHT OF THE SPECIFIC WALL COMPONENT. THE HEIGHT OF A SPECIFIC WALL COMPONENT. REFER TO THE LEGEND BELOW. THIS SYSTEM IS USED TO DEFINE WALL TYPES: RA THRU RR.

NUMERIC CHARACTER	CMU/BRICK HEIGHT
1	9' - 4"
2	10' - 8"
3	12' - 8"
4	16' - 8"
14	14' - 0"
- IF NO SYMBOL DESIGNATION IS PROVIDED, FOR A PARTITION ON THE FLOOR PLANS, THE WALL TYPE SHALL BE AN A3 WITH SOUND BATTS.
- THE GRAPHIC DESIGNATION IS INCORPORATED FOR PARTITIONS REQUIRED TO BE SMOKE RESISTANT, FIRE RESISTANT, OR BOTH FIRE AND SMOKE RESISTANT. REFER TO NOTE 18.
- "LINE OF STRUCTURE" INDICATED FOR EACH PARTITION IS DIAGRAMMATIC ONLY AND DOES NOT INDICATE EXACT CONSTRUCTION CONDITIONS OR GEOMETRY.
- ALL DIMENSIONS ARE FROM FACE OF GYPSUM BOARD TO FACE OF GYPSUM BOARD. REFER TO PARTITION MATRICES FOR PARTITION WIDTH DIMENSIONS UNLESS INDICATED TO BE SHOWN ON PLAN.
- SEALANT:
 - FIRE RESISTANCE RATED PARTITIONS SHALL USE RATED FIRE/SMOKE FIRE RESISTANT FILL MATERIAL IN CONJUNCTION WITH AN APPROPRIATE RATED FIRE/SMOKE FIRE STOPPING SYSTEM.
 - NON-RATED PARTITIONS AND NON-RATED SMOKE RESISTANT PARTITIONS SHALL USE ACOUSTICAL SEALANT.
- INSULATION - HEAD CONDITIONS AT FLOOR/ROOF DECK:
 - FIRE RESISTANCE RATED PARTITIONS SHALL USE MINERAL WOOL INSULATION.
 - NON-RATED PARTITIONS REQUIRING SOUND ATTENUATION SHALL USE SOUND ATTENUATION BLANKETS (SAB).
 - PROVIDE FULL THICKNESS INSULATION INSIDE ALL STUD BOX BEAMS AND HEADERS WHICH OCCUR IN WALLS WITH SOUND ATTENUATION.
- REFER TO SPECIFICATIONS FOR MINIMUM STUD THICKNESS, MAXIMUM SPACING AND ALLOWABLE LIMITING HEIGHTS DEFLECTION CRITERIA FOR GYPSUM BOARD ASSEMBLIES.
- FOR PARTITIONS INDICATED TO RECEIVE SOUND ATTENUATION BLANKETS (SAB), EXTEND SAB TO FULL HEIGHT OF PARTITION UNLESS OTHERWISE INDICATED.
- FIRE RESISTANT AND FIRE RESISTANT SMOKE BARRIER RATINGS ARE TO SURROUND ALL OPENINGS IN RATED PARTITIONS.


TYPE "J"							
FLOOR PLAN DESIGNATION NO SOUND ATTENUATION	FLOOR PLAN DESIGNATION WITH SOUND ATTENUATION	STUD SIZE	PART WIDTH	FIRE RATING	UL LISTING	SOUND TRANS. CLASS	LABORATORY TEST REPORT & REMARKS
	N/A	2 1/2"	3 1/8"	NON-RATED	N/A	N/A	
	N/A	3 5/8"	4 1/4"	NON-RATED	N/A	N/A	
	N/A	6"	6 5/8"	NON-RATED	N/A	N/A	

TYPE "D"							
FLOOR PLAN DESIGNATION NO SOUND ATTENUATION	FLOOR PLAN DESIGNATION WITH SOUND ATTENUATION	STUD SIZE	PART WIDTH	FIRE RATING	UL LISTING	STC: NO SOUND WITH SOUND	LABORATORY TEST REPORT & REMARKS
		2 1/2"	3 3/4"	TWO HOUR	U438	48 - 49 (W 2 1/2" SAB)	USG - 161222
		4"	5 1/4"	TWO HOUR	U438	48 - 51 (W 3 1/2" SAB)	
		6"	7 1/4"	TWO HOUR	U438	50 - 52 (W 6" SAB)	

- SMOKE RESISTANT, FIRE RESISTANT, AND FIRE RESISTANT SMOKE BARRIER PARTITIONS SHALL EXTEND AND SEAL TO INSIDE FACE OF EXTERIOR SHEATHING, INCLUDING EXTENSIONS THROUGH SOFFITS.
- EACH PARTITION SHOWN ON THE DRAWINGS TO HAVE A FIRE AND SMOKE RESISTANT RATING SHALL BE IDENTIFIED AS SUCH WITH A LABEL ABOVE THE CEILING ON EACH SEGMENT OF THE WALL AND 0'-0" OC MAX EACH SEGMENT.
- REFER TO TOILET ACCESSORIES SHEET AND CASEWORK SHEET FOR MOUNTING DETAIL INFORMATION.
- REFER TO THE METAL FABRICATIONS DETAILS FOR MF REFERENCES IN PARTITIONS SECTION.
- REFER TO STRUCTURAL DRAWINGS FOR REINFORCING INFORMATION.
- GRAPHIC DESIGNATION


	PRIORITY
4 HR FIRE BARRIER	1 HIGHEST
3 HR FIRE BARRIER	2
2 HR SMOKE BARRIER	3
2 HR FIRE BARRIER	
2 HR FIRE BARRIER/SHAFT WALL	
1 HR SMOKE BARRIER	4
1 HR FIRE BARRIER	
1 HR FIRE BARRIER/SHAFT WALL	5 LOWEST
SMOKE PARTITION (NON RATED)	
- DO NOT APPLY BULLNOSE BLOCK AT CORNER GUARD LOCATIONS.
- MASONRY REINFORCEMENT: REFERENCE STRUCTURAL DRAWINGS.
- HW (HEAD OF WALL) DETAILS DO NOT ALTER PARTITION TYPES NOTED ON PLANS.
- ALL STC RATINGS ARE BASED ON 20 GA STUDS AT 16" OC, UNLESS NOTED OTHERWISE (U,N,O).
- ALL STC RATINGS ARE DERIVED FROM LABORATORY TESTS OR VALUES EXTRAPOLATED USING FUNDAMENTAL ACOUSTIC PRINCIPLES.
- PROVIDE SOFT BODY/HARD BODY WALL ASSEMBLIES FOR INTERIOR EXIT STAIRWAYS AND ELEVATOR HOISTWAYS AS INDICATED IN SPECIFICATIONS.

NOTE:	
1. NOT ALL PARTITION TYPES SHOWN ON THIS SHEET ARE USED ON THIS PROJECT.	
2. THE SHADED PORTIONS OF A PARTITION TYPE ARE NOT INCLUDED IN THE SCOPE OF THE WORK.	
3. THE UN-SHADED PORTIONS OF ALL PARTITION TYPES ARE INTENDED TO BE IN THE SCOPE OF THE WORK.	
HATCHING:	
	PARTITION TYPE INCLUDED IN SCOPE OF WORK
	PARTITION TYPE NOT INCLUDED IN SCOPE OF WORK




METAL COPING DETAIL - SINGLE PLY ROOFING

1 1/2" = 1'-0"




SHEET METAL SILL FLASHING END DAM

NTS




SHEET METAL DRIP FLASHING

NTS




SHEET METAL DRIP FLASHING

3" = 1'-0"




SHEET METAL JAMB AND SILL FLASHING

NTS




HOLLOW METAL DOOR FRAME AT JAMB

3" = 1'-0"




CONTROL JOINT INTERSECTION

NTS




CONTROL JOINT TERMINATION

NTS



EXPANSION JOINT TERMINATION

NTS



DIRECT BOND PLASTER SYSTEM

NTS


RESERVE FOR DCA STAMP

HKS

ARCHITECT
HKS, P.C.
1250 I EYE) STREET NW, SUITE 600
WASHINGTON, DC 20005
STRUCTURAL ENGINEER
ODONWELL & MACCARATO
701 MARKET ST. #2000
PHILADELPHIA, PA 19106
MEP-FP / LOW VOLTAGE ENGINEER
BR-A CONSULTING ENGINEERS
2401 WALNUT ST SUITE 701
PHILADELPHIA, PA 19103
HIGHLAND ASSOCIATES
102 HIGHLAND AVE
CLARKS SUMMIT, PA 18411

Cooper University Health Care
COOPER UNIVERSITY
HOSPITAL - CUP EXT

OWNER
COOPER UNIVERSITY HEALTHCARE
1 COOPER PLAZA
CAMDEN, NJ 08103
PROJECT MANAGER
PURE PM
2026 RICHMOND STREET
PHILADELPHIA, PA 19134
CIVIL ENGINEER
LANGAN
1818 MARKET STREET, SUITE 3800
PHILADELPHIA, PA 19103
SEAL & SINGATURE









REVISION	NO.	DESCRIPTION	DATE
1	BULLETIN 10		04/03/26

HKS PROJECT NUMBER
25695.150
DATE
04/07/2025
ISSUE
ISSUED FOR PERMIT

SHEET TITLE
DIRECT BOND PLASTER
DETAILS & PARTITION
TYPES
SHEET NO.

UA7.09

TITLE BLOCK VERSION: 20210830
MODEL: Autodesk Docs (25695.00) Cooper Medical Campus Plan 2023A_CUP-CUP 2023.rvt
PRINT DATE: 03/20/26 4:49:12 PM
TEMPLATE VERSION: 23.0.3



RESERVE FOR DCA STAMP

HKS

ARCHITECT
HKS, P.C.
1250 I (EYE) STREET NW, SUITE 600
WASHINGTON, DC 20005

STRUCTURAL ENGINEER
ODONWELL & MACCARATO
701 MARKET ST. #600
PHILADELPHIA, PA 19106

MEP-FP / LOW VOLTAGE ENGINEER
BR-A CONSULTING ENGINEERS
2401 WALNUT ST SUITE 701
PHILADELPHIA, PA 19103
HIGHLAND ASSOCIATES
102 HIGHLAND AVE
CLARKS SUMMIT, PA 18411

Cooper
University Health Care

COOPER UNIVERSITY HOSPITAL - CUP EXT


PROJECT ADDRESS: 1 COOPER PLAZA, CAMDEN, NJ 08103

OWNER
COOPER UNIVERSITY HEALTHCARE
1 COOPER PLAZA
CAMDEN, NJ 08103

PROJECT MANAGER
PURE PM
2026 RICHMOND STREET
PHILADELPHIA, PA 19134

CIVIL ENGINEER
LANGAN
1818 MARKET STREET, SUITE 3800
PHILADELPHIA, PA 19103
SEAL & SINGATURE

KEY PLAN



REVISION	NO.	DESCRIPTION	DATE
1	RFI #248		06/19/25
2	DCA Review		10/07/25

HKS PROJECT NUMBER
25695.150

DATE
04/07/2025

ISSUE
ISSUED FOR PERMIT

SHEET TITLE
CONDUIT DETAILS

SHEET NO.

UA7.11

BUILDING PERMIT NUMBER: 1111

© HKS, INC.