

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT				
Serial No: SR-000008	Report No: 1	Visit Date: 2026-07-20	Complaint No: 1	Unit Type: Warranty
CUSTOMER NAME & ADDRESS:		PROBLEM REPORTED:	OBSERVATION & ACTION TAKEN:	
GANDHI HOSPITAL		General service	Filters changed and fr replaced	
		SPARES REQUIRED: FR 800		
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	GANDHI HOSPITAL	Raw Water TDS	50	
Plant Capacity	50 lph	Product Water TDS	100	
Design R/W TDS	2000	Product Water Flow in LPH	50.0	
Free Chlorine in R/W	2000	Sensors Condition	OK	
No. of Hours Running	3hrs	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	230.0	
UV Lamp Condition	OK	Current in Amps	52	
SPARES CONSUMED				
FR 800				
CUSTOMER NAME / MOBILE NUMBER		CUSTOMER SIGNATURE & DATE	SCHOOL STAMP	
Uma 53783i292			(no stamp on file)	
SERVICE ENGINEER: RAGHAVENDRA		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: —				