

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT				
Serial No: SR-000007	Report No: 01	Visit Date: 2026-07-20	Complaint No: 01	Unit Type: AMC
CUSTOMER NAME & ADDRESS:		PROBLEM REPORTED:	OBSERVATION & ACTION TAKEN:	
vemulakonda village		Nathig	Nathig	
		SPARES REQUIRED: 10		
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	vemulakonda village	Raw Water TDS	255	
Plant Capacity	1000	Product Water TDS	255	
Design R/W TDS	700	Product Water Flow in LPH	255.0	
Free Chlorine in R/W	5lt	Sensors Condition	OK	
No. of Hours Running	2000	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	255.0	
UV Lamp Condition	OK	Current in Amps	255	
SPARES CONSUMED				
10				
CUSTOMER NAME / MOBILE NUMBER		CUSTOMER SIGNATURE & DATE	SCHOOL STAMP	
Rasul 96728363838			(no stamp on file)	
SERVICE ENGINEER: NAYEEM		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: Ok				

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623