

# SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

| WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT |                   |                               |                             |                |
|--------------------------------------------------------------------------------|-------------------|-------------------------------|-----------------------------|----------------|
| Serial No: SR-000005                                                           | Report No: 3105   | Visit Date: 2026-07-20        | Complaint No: 1             | Unit Type: AMC |
| CUSTOMER NAME & ADDRESS:                                                       |                   | PROBLEM REPORTED:             | OBSERVATION & ACTION TAKEN: |                |
| GOVT.PS FISHERIES                                                              |                   | Running water tank problem    | MCF feliter change          |                |
|                                                                                |                   | SPARES REQUIRED: 500lits tank |                             |                |
| UNIT DETAILS / SITE CONDITION                                                  |                   | PLANT READINGS                |                             |                |
| Plant Location                                                                 | GOVT.PS FISHERIES | Raw Water TDS                 | 700                         |                |
| Plant Capacity                                                                 | 50lph             | Product Water TDS             | 70                          |                |
| Design R/W TDS                                                                 | 700               | Product Water Flow in LPH     | 50.0                        |                |
| Free Chlorine in R/W                                                           | Good              | Sensors Condition             | OK                          |                |
| No. of Hours Running                                                           | 2hrs              | Pre-Filter Condition          | OK                          |                |
| Membrane Condition                                                             | OK                | Voltage                       | 220.0                       |                |
| UV Lamp Condition                                                              | OK                | Current in Amps               | 6                           |                |
| SPARES CONSUMED                                                                |                   |                               |                             |                |
| 500lits tank                                                                   |                   |                               |                             |                |
| CUSTOMER NAME / MOBILE NUMBER                                                  |                   | CUSTOMER SIGNATURE & DATE     | SCHOOL STAMP                |                |
| K. V satyaveni 944085990                                                       |                   |                               | (no stamp on file)          |                |
| SERVICE ENGINEER: MANIKANTA                                                    |                   | STATUS: PROBLEM RESOLVED      |                             |                |
| SERVICE ENGINEER SIGNATURE:                                                    |                   |                               |                             |                |
| Customer Remarks: —                                                            |                   |                               |                             |                |

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623