

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT				
Serial No: SR-000009	Report No: 1	Visit Date: 2026-07-20	Complaint No: 1	Unit Type: Warranty
CUSTOMER NAME & ADDRESS:		PROBLEM REPORTED:	OBSERVATION & ACTION TAKEN:	
NIEPIED (BOWENPALLY)		General service	Filters change & back wash & Dosing water adding	
		SPARES REQUIRED: 1		
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	NIEPIED (BOWENPALLY)	Raw Water TDS	456	
Plant Capacity	250	Product Water TDS	50	
Design R/W TDS	2000ppm	Product Water Flow in LPH	250.0	
Free Chlorine in R/W	1	Sensors Condition	OK	
No. of Hours Running	2	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	210.0	
UV Lamp Condition	OK	Current in Amps	4.5	
SPARES CONSUMED				
1				
CUSTOMER NAME / MOBILE NUMBER		CUSTOMER SIGNATURE & DATE		SCHOOL STAMP
Chary 9060524630				(no stamp on file)
SERVICE ENGINEER: RAGHAVENDRA		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: —				

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623