

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT

Serial No: PENDING VERIFICATION	Report No: 3106	Visit Date: 2026-07-20	Complaint No: 3106	Unit Type: AMC
CUSTOMER NAME & ADDRESS:	PROBLEM REPORTED:		OBSERVATION & ACTION TAKEN:	
MCPS TOWN HALL	RO Plant wheels damage		Mcf filter change	
	SPARES REQUIRED: MCF			
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	MCPS TOWN HALL	Raw Water TDS	850	
Plant Capacity	50lph	Product Water TDS	85	
Design R/W TDS	850	Product Water Flow in LPH	50.0	
Free Chlorine in R/W	Good	Sensors Condition	OK	
No. of Hours Running	4 hours	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	220.0	
UV Lamp Condition	OK	Current in Amps	5	
SPARES CONSUMED				
MCF				
CUSTOMER NAME / MOBILE NUMBER	CUSTOMER SIGNATURE & DATE		SCHOOL STAMP	
R. Demudu babu 9963155234			(no stamp on file)	
SERVICE ENGINEER: MANIKANTA		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: —				

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623