

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT

Serial No: PENDING VERIFICATION	Report No: 5083	Visit Date: 2026-07-20	Complaint No: Amc visit	Unit Type: AMC
CUSTOMER NAME & ADDRESS:	PROBLEM REPORTED:		OBSERVATION & ACTION TAKEN:	
Mpps bangarigadda	Amc visit		Plant cheking and filter changed and flow cheking and tds cheking and plant runding is good	
		SPARES REQUIRED: Mcf-2/cto		
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	Mpps bangarigadda	Raw Water TDS	230	
Plant Capacity	50 lph	Product Water TDS	41	
Design R/W TDS	1500	Product Water Flow in LPH	50.0	
Free Chlorine in R/W	-	Sensors Condition	OK	
No. of Hours Running	2hr	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	230.0	
UV Lamp Condition	OK	Current in Amps	2.5	
SPARES CONSUMED				
Mcf-2/cto				
CUSTOMER NAME / MOBILE NUMBER	CUSTOMER SIGNATURE & DATE		SCHOOL STAMP	
m.venkashwarlu 9492506386			(no stamp on file)	
SERVICE ENGINEER: MADHU		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: —				

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623