

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT				
Serial No: PENDING VERIFICATION	Report No: 3107	Visit Date: 2026-07-20	Complaint No: 3107	Unit Type: AMC
CUSTOMER NAME & ADDRESS:	PROBLEM REPORTED:		OBSERVATION & ACTION TAKEN:	
MCPS GANDHIGRAM	Rw pipe 8mm Damage		MCF 8mm tub change	
	SPARES REQUIRED: 8mm tube, MCF			
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	MCPS GANDHIGRAM	Raw Water TDS	750	
Plant Capacity	100lph	Product Water TDS	68	
Design R/W TDS	770	Product Water Flow in LPH	100.0	
Free Chlorine in R/W	Good	Sensors Condition	OK	
No. of Hours Running	4 hours	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	220.0	
UV Lamp Condition	OK	Current in Amps	6	
SPARES CONSUMED				
8mm tube, MCF				
CUSTOMER NAME / MOBILE NUMBER	CUSTOMER SIGNATURE & DATE		SCHOOL STAMP	
M. Kavitha 9642712544			(no stamp on file)	
SERVICE ENGINEER: MANIKANTA		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: —				

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623