

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT				
Serial No: PENDING VERIFICATION	Report No: 1	Visit Date: 2026-07-20	Complaint No: 1	Unit Type: Warranty
CUSTOMER NAME & ADDRESS:	PROBLEM REPORTED:		OBSERVATION & ACTION TAKEN:	
shishuvihar	General service		Filters change & back wash & Dosing water adding	
		SPARES REQUIRED: MCF (Micron filters)		
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	shishuvihar	Raw Water TDS	580	
Plant Capacity	1000	Product Water TDS	60	
Design R/W TDS	2000	Product Water Flow in LPH	1000.0	
Free Chlorine in R/W	1	Sensors Condition	OK	
No. of Hours Running	2	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	230.0	
UV Lamp Condition	OK	Current in Amps	14	
SPARES CONSUMED				
MCF (Micron filters)				
CUSTOMER NAME / MOBILE NUMBER	CUSTOMER SIGNATURE & DATE		SCHOOL STAMP	
Santhi 9440105019			(no stamp on file)	
SERVICE ENGINEER: RAGHAVENDRA		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: —				

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623