

# SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

| WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT |                           |                           |                              |                |
|--------------------------------------------------------------------------------|---------------------------|---------------------------|------------------------------|----------------|
| Serial No: <b>PENDING VERIFICATION</b>                                         | Report No: 008            | Visit Date: 2026-07-20    | Complaint No: 008            | Unit Type: AMC |
| CUSTOMER NAME & ADDRESS:                                                       | PROBLEM REPORTED:         |                           | OBSERVATION & ACTION TAKEN:  |                |
| dharmojigudem village                                                          | Filter s                  |                           | Filters changed tds checking |                |
|                                                                                |                           | SPARES REQUIRED: 3 mcf    |                              |                |
| UNIT DETAILS / SITE CONDITION                                                  |                           | PLANT READINGS            |                              |                |
| Plant Location                                                                 | dharmojigudem village     | Raw Water TDS             | 1280                         |                |
| Plant Capacity                                                                 | 500                       | Product Water TDS         | 60                           |                |
| Design R/W TDS                                                                 | 2000                      | Product Water Flow in LPH | 500.0                        |                |
| Free Chlorine in R/W                                                           | .                         | Sensors Condition         | OK                           |                |
| No. of Hours Running                                                           | 3                         | Pre-Filter Condition      | OK                           |                |
| Membrane Condition                                                             | OK                        | Voltage                   | 230.0                        |                |
| UV Lamp Condition                                                              | OK                        | Current in Amps           | 10                           |                |
| SPARES CONSUMED                                                                |                           |                           |                              |                |
| 3 mcf                                                                          |                           |                           |                              |                |
| CUSTOMER NAME / MOBILE NUMBER                                                  | CUSTOMER SIGNATURE & DATE |                           | SCHOOL STAMP                 |                |
| Srinivas 9110540592                                                            |                           |                           | (no stamp on file)           |                |
| SERVICE ENGINEER: KAMALAKAR                                                    |                           | STATUS: PROBLEM RESOLVED  |                              |                |
| SERVICE ENGINEER SIGNATURE:                                                    |                           |                           |                              |                |
| Customer Remarks: —                                                            |                           |                           |                              |                |

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623