

# SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

| WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT |                           |                           |                                                  |                |
|--------------------------------------------------------------------------------|---------------------------|---------------------------|--------------------------------------------------|----------------|
| Serial No: SR-000010                                                           | Report No: 01             | Visit Date: 2026-07-25    | Complaint No: 02                                 | Unit Type: AMC |
| CUSTOMER NAME & ADDRESS:                                                       | PROBLEM REPORTED:         |                           | OBSERVATION & ACTION TAKEN:                      |                |
| NELAPALTA VILLAGE                                                              | Plant working good        |                           | Back wash completed Dosing added MCF FILTER good |                |
|                                                                                |                           | SPARES REQUIRED: MCF      |                                                  |                |
| UNIT DETAILS / SITE CONDITION                                                  |                           | PLANT READINGS            |                                                  |                |
| Plant Location                                                                 | NELAPALTA VILLAGE         | Raw Water TDS             | 780                                              |                |
| Plant Capacity                                                                 | 1000                      | Product Water TDS         | 60                                               |                |
| Design R/W TDS                                                                 | 2000                      | Product Water Flow in LPH | 1000.0                                           |                |
| Free Chlorine in R/W                                                           | 100ml                     | Sensors Condition         | OK                                               |                |
| No. of Hours Running                                                           | 4                         | Pre-Filter Condition      | OK                                               |                |
| Membrane Condition                                                             | OK                        | Voltage                   | 230.0                                            |                |
| UV Lamp Condition                                                              | OK                        | Current in Amps           | 10                                               |                |
| SPARES CONSUMED                                                                |                           |                           |                                                  |                |
| MCF                                                                            |                           |                           |                                                  |                |
| CUSTOMER NAME / MOBILE NUMBER                                                  | CUSTOMER SIGNATURE & DATE |                           | SCHOOL STAMP                                     |                |
| Narayana 9912643259                                                            |                           |                           | (no stamp on file)                               |                |
| SERVICE ENGINEER: NAYEEM                                                       |                           | STATUS: PROBLEM RESOLVED  |                                                  |                |
| SERVICE ENGINEER SIGNATURE:                                                    |                           |                           |                                                  |                |
| Customer Remarks: —                                                            |                           |                           |                                                  |                |