

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT				
Serial No: PENDING VERIFICATION	Report No: 1	Visit Date: 2026-07-25	Complaint No: 1	Unit Type: AMC
CUSTOMER NAME & ADDRESS:	PROBLEM REPORTED:		OBSERVATION & ACTION TAKEN:	
JALUKALWA VILLAGE	Good working		Back wach and filters changed	
		SPARES REQUIRED: 3		
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	JALUKALWA VILLAGE	Raw Water TDS	802	
Plant Capacity	1000	Product Water TDS	60	
Design R/W TDS	2000	Product Water Flow in LPH	1000.0	
Free Chlorine in R/W	200ml	Sensors Condition	OK	
No. of Hours Running	5	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	230.0	
UV Lamp Condition	OK	Current in Amps	11	
SPARES CONSUMED				
3				
CUSTOMER NAME / MOBILE NUMBER	CUSTOMER SIGNATURE & DATE		SCHOOL STAMP	
Chendhu 8499028964			(no stamp on file)	
SERVICE ENGINEER: NAYEEM		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: —				