

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT				
Serial No: PENDING VERIFICATION	Report No: 012	Visit Date: 2026-07-25	Complaint No: 012	Unit Type: AMC
CUSTOMER NAME & ADDRESS:	PROBLEM REPORTED:		OBSERVATION & ACTION TAKEN:	
MPPS SEETHAVANIGUDEM	Need raw pump 0.5hp		Need pump parashally working	
		SPARES REQUIRED: Need to above material		
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	MPPS SEETHAVANIGUDEM	Raw Water TDS	772	
Plant Capacity	50	Product Water TDS	-1	
Design R/W TDS	1500	Product Water Flow in LPH	-1.0	
Free Chlorine in R/W	F	Sensors Condition	OK	
No. of Hours Running	-	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	-230.0	
UV Lamp Condition	OK	Current in Amps	-1	
SPARES CONSUMED				
Need to above material				
CUSTOMER NAME / MOBILE NUMBER	CUSTOMER SIGNATURE & DATE		SCHOOL STAMP	
Shanndeisa 998104715			(no stamp on file)	
SERVICE ENGINEER: KAMALAKAR		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: Need pump				

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623