

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT

Serial No: PENDING VERIFICATION	Report No: 03	Visit Date: 2026-07-25	Complaint No: 03	Unit Type: AMC
CUSTOMER NAME & ADDRESS:	PROBLEM REPORTED:		OBSERVATION & ACTION TAKEN:	
ZPHS REVIDI	Membrane complint		Problem solve	
		SPARES REQUIRED: RO Membrane		
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	ZPHS REVIDI	Raw Water TDS	770	
Plant Capacity	50	Product Water TDS	80	
Design R/W TDS	770	Product Water Flow in LPH	50.0	
Free Chlorine in R/W	Ok	Sensors Condition	OK	
No. of Hours Running	2	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	220.0	
UV Lamp Condition	OK	Current in Amps	5	
SPARES CONSUMED				
RO Membrane				
CUSTOMER NAME / MOBILE NUMBER	CUSTOMER SIGNATURE & DATE		SCHOOL STAMP	
Someswara rao 8309197175			(no stamp on file)	
SERVICE ENGINEER: MANIKANTA		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: —				

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623