

# SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

## WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT

| <b>Serial No: PENDING VERIFICATION</b> | <b>Report No: 04</b>                 | <b>Visit Date: 2026-07-25</b>    | <b>Complaint No: 04</b>                | <b>Unit Type: AMC</b> |
|----------------------------------------|--------------------------------------|----------------------------------|----------------------------------------|-----------------------|
| <b>CUSTOMER NAME &amp; ADDRESS:</b>    | <b>PROBLEM REPORTED:</b>             |                                  | <b>OBSERVATION &amp; ACTION TAKEN:</b> |                       |
| ZPHS B.R.TALLAVALASA                   | Rw pipe complint                     |                                  | 8mm pipe change                        |                       |
|                                        | <b>SPARES REQUIRED:</b> 8mm tube     |                                  |                                        |                       |
| UNIT DETAILS / SITE CONDITION          |                                      | PLANT READINGS                   |                                        |                       |
| <b>Plant Location</b>                  | ZPHS B.R.TALLAVALASA                 | <b>Raw Water TDS</b>             | 710                                    |                       |
| <b>Plant Capacity</b>                  | 50lph                                | <b>Product Water TDS</b>         | 82                                     |                       |
| <b>Design R/W TDS</b>                  | 710ppm                               | <b>Product Water Flow in LPH</b> | 50.0                                   |                       |
| <b>Free Chlorine in R/W</b>            | Ok                                   | <b>Sensors Condition</b>         | OK                                     |                       |
| <b>No. of Hours Running</b>            | 2hrs                                 | <b>Pre-Filter Condition</b>      | OK                                     |                       |
| <b>Membrane Condition</b>              | OK                                   | <b>Voltage</b>                   | 230.0                                  |                       |
| <b>UV Lamp Condition</b>               | OK                                   | <b>Current in Amps</b>           | 6                                      |                       |
| SPARES CONSUMED                        |                                      |                                  |                                        |                       |
| 8mm tube                               |                                      |                                  |                                        |                       |
| <b>CUSTOMER NAME / MOBILE NUMBER</b>   | <b>CUSTOMER SIGNATURE &amp; DATE</b> |                                  | <b>SCHOOL STAMP</b>                    |                       |
| Sanyasi Naidu 9888955599               |                                      |                                  | (no stamp on file)                     |                       |
| <b>SERVICE ENGINEER: MANIKANTA</b>     |                                      | <b>STATUS: PROBLEM RESOLVED</b>  |                                        |                       |
| <b>SERVICE ENGINEER SIGNATURE:</b>     |                                      |                                  |                                        |                       |
| <b>Customer Remarks: —</b>             |                                      |                                  |                                        |                       |

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623