

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT

Serial No: PENDING VERIFICATION	Report No: 05	Visit Date: 2026-07-25	Complaint No: 05	Unit Type: AMC
CUSTOMER NAME & ADDRESS:	PROBLEM REPORTED:		OBSERVATION & ACTION TAKEN:	
MPPS KORADA	Smpls complint		Problem solve	
		SPARES REQUIRED: Low pressure switch		
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	MPPS KORADA	Raw Water TDS	810	
Plant Capacity	100lph	Product Water TDS	70	
Design R/W TDS	810ppm	Product Water Flow in LPH	100.0	
Free Chlorine in R/W	Ok	Sensors Condition	OK	
No. of Hours Running	4hrs	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	230.0	
UV Lamp Condition	OK	Current in Amps	6	
SPARES CONSUMED				
Low pressure switch				
CUSTOMER NAME / MOBILE NUMBER	CUSTOMER SIGNATURE & DATE		SCHOOL STAMP	
Sankar rao 9550605906			(no stamp on file)	
SERVICE ENGINEER: MANIKANTA		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: —				

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623