

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT				
Serial No: PENDING VERIFICATION	Report No: 1	Visit Date: 2026-07-27	Complaint No: 1	Unit Type: Warranty
CUSTOMER NAME & ADDRESS:	PROBLEM REPORTED:		OBSERVATION & ACTION TAKEN:	
OSMANIA HOSPITAL	General service visiting		Filters change & back wash & Dosing water adding	
		SPARES REQUIRED: 2 micron filters		
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	OSMANIA HOSPITAL	Raw Water TDS	450	
Plant Capacity	500 lph	Product Water TDS	65	
Design R/W TDS	2000	Product Water Flow in LPH	500.0	
Free Chlorine in R/W	268	Sensors Condition	OK	
No. of Hours Running	3 hr	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	215.0	
UV Lamp Condition	OK	Current in Amps	13	
SPARES CONSUMED				
2 micron filters				
CUSTOMER NAME / MOBILE NUMBER	CUSTOMER SIGNATURE & DATE		SCHOOL STAMP	
Kavita 9951190164			(no stamp on file)	
SERVICE ENGINEER: RAGHAVENDRA		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: —				