

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT				
Serial No: PENDING VERIFICATION	Report No: 02	Visit Date: 2026-07-28	Complaint No: 02	Unit Type: AMC
CUSTOMER NAME & ADDRESS:	PROBLEM REPORTED:		OBSERVATION & ACTION TAKEN:	
kanumukkula village	Plant working good		Flow and TDS working good Back washing completed Filter change	
		SPARES REQUIRED: 3 nos		
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	kanumukkula village	Raw Water TDS	790	
Plant Capacity	1000	Product Water TDS	70	
Design R/W TDS	2000	Product Water Flow in LPH	1000.0	
Free Chlorine in R/W	2ml	Sensors Condition	OK	
No. of Hours Running	4	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	230.0	
UV Lamp Condition	OK	Current in Amps	12	
SPARES CONSUMED				
3 nos				
CUSTOMER NAME / MOBILE NUMBER		CUSTOMER SIGNATURE & DATE		SCHOOL STAMP
Naven 9951794268				(no stamp on file)
SERVICE ENGINEER: NAYEEM		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: —				