

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT				
Serial No: PENDING VERIFICATION	Report No: 014	Visit Date: 2026-07-28	Complaint No: 014	Unit Type: AMC
CUSTOMER NAME & ADDRESS:	PROBLEM REPORTED:		OBSERVATION & ACTION TAKEN:	
MPPS Dharmojigudem	Sv problem		Plant checking and new sv changed plant ok good	
		SPARES REQUIRED: Sv 1		
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	MPPS Dharmojigudem	Raw Water TDS	1100	
Plant Capacity	50	Product Water TDS	120	
Design R/W TDS	1500	Product Water Flow in LPH	50.0	
Free Chlorine in R/W	200	Sensors Condition	OK	
No. of Hours Running	2	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	230.0	
UV Lamp Condition	OK	Current in Amps	1	
SPARES CONSUMED				
Sv 1				
CUSTOMER NAME / MOBILE NUMBER	CUSTOMER SIGNATURE & DATE		SCHOOL STAMP	
Sunitha 7702309910			(no stamp on file)	
SERVICE ENGINEER: KAMALAKAR		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: —				