

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT				
Serial No: SR-000011	Report No: Service	Visit Date: 2026-07-28	Complaint No: 2	Unit Type: AMC
CUSTOMER NAME & ADDRESS:		PROBLEM REPORTED:	OBSERVATION & ACTION TAKEN:	
VARRIGUDEM		Service power	Checking filters good and cleaning filters and Checking fr good and observation of all leakages good and Checking power good	
		SPARES REQUIRED: No		
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	VARRIGUDEM	Raw Water TDS	287	
Plant Capacity	100lph	Product Water TDS	32	
Design R/W TDS	287	Product Water Flow in LPH	100.0	
Free Chlorine in R/W	No	Sensors Condition	OK	
No. of Hours Running	1hr	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	230.0	
UV Lamp Condition	OK	Current in Amps	24	
SPARES CONSUMED				
No				
CUSTOMER NAME / MOBILE NUMBER		CUSTOMER SIGNATURE & DATE		SCHOOL STAMP
Varregudam 9248360495				(no stamp on file)
SERVICE ENGINEER: SUNNY		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: —				

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623