

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT				
Serial No: PENDING VERIFICATION	Report No: 03	Visit Date: 2026-07-28	Complaint No: 03	Unit Type: AMC
CUSTOMER NAME & ADDRESS:	PROBLEM REPORTED:		OBSERVATION & ACTION TAKEN:	
Danthur village	Plant working good		Atw Buttons not working New consumed	
		SPARES REQUIRED: 3 nos , buttons 1		
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	Danthur village	Raw Water TDS	900	
Plant Capacity	1000	Product Water TDS	72	
Design R/W TDS	2000	Product Water Flow in LPH	1000.0	
Free Chlorine in R/W	200ml	Sensors Condition	OK	
No. of Hours Running	4	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	230.0	
UV Lamp Condition	OK	Current in Amps	10	
SPARES CONSUMED				
3 nos , buttons 1				
CUSTOMER NAME / MOBILE NUMBER	CUSTOMER SIGNATURE & DATE		SCHOOL STAMP	
Shiva 9666299079			(no stamp on file)	
SERVICE ENGINEER: NAYEEM		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: —				

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623