

SRI HAMSINI & CHANDRA ENTERPRISES

Office Address: 2-1-49/244, Park Street, Street No. 17, Suryanagar Colony, Uppal, Hyderabad, Telangana - 500039

WATER PURIFICATION UNIT: INSTALLATION / COMMISSIONING / SERVICE / VISIT REPORT

Serial No: PENDING VERIFICATION	Report No: 6923	Visit Date: 2026-07-28	Complaint No: Service call	Unit Type: AMC
CUSTOMER NAME & ADDRESS:	PROBLEM REPORTED:		OBSERVATION & ACTION TAKEN:	
zphs nampally unit-1	Service call		Plant cheking and filter cheking and flow cheking and tds cheking and plant runding is good	
		SPARES REQUIRED: Membrane -1, membrane housing -1		
UNIT DETAILS / SITE CONDITION		PLANT READINGS		
Plant Location	zphs nampally unit-1	Raw Water TDS	810	
Plant Capacity	100lph	Product Water TDS	72	
Design R/W TDS	1500	Product Water Flow in LPH	100.0	
Free Chlorine in R/W	-	Sensors Condition	OK	
No. of Hours Running	2hr	Pre-Filter Condition	OK	
Membrane Condition	OK	Voltage	230.0	
UV Lamp Condition	OK	Current in Amps	2.4	
SPARES CONSUMED				
Membrane -1, membrane housing -1				
CUSTOMER NAME / MOBILE NUMBER	CUSTOMER SIGNATURE & DATE		SCHOOL STAMP	
Ajay Kumar 9866426934			(no stamp on file)	
SERVICE ENGINEER: MADHU		STATUS: PROBLEM RESOLVED		
SERVICE ENGINEER SIGNATURE:				
Customer Remarks: —				

E-mail Id: ch.srini1979@yahoo.com / ch.srini1979@rediffmail.com Tel No. 7670873623